

UNCLASSIFIED

AD NUMBER

ADB000632

LIMITATION CHANGES

TO:

Approved for public release; distribution is unlimited.

FROM:

Distribution authorized to U.S. Gov't. agencies only; Test and Evaluation; OCT 1074. Other requests shall be referred to Rome Air Development Center, Attn: DCLD, Griffiss AFB, NY 13441.

AUTHORITY

RADC ltr, 3 May 1979

THIS PAGE IS UNCLASSIFIED

THIS REPORT HAS BEEN DELIMITED
AND CLEARED FOR PUBLIC RELEASE
UNDER DOD DIRECTIVE 5200.20 AND
NO RESTRICTIONS ARE IMPOSED UPON
ITS USE AND DISCLOSURE.

DISTRIBUTION STATEMENT A

APPROVED FOR PUBLIC RELEASE;
DISTRIBUTION UNLIMITED.

7

RADC-TR-74-258
Final Report
October 1974



AIR FORCE COMMUNICATIONS SERVICE
DIGITAL TRANSMISSION STUDY

Volume I
Test Results

Appendix
Computer Analysis
of
Isochronous Distortion Data

Computer Sciences Corporation



Distribution limited to US Gov't agencies
only; test and evaluation; October 1974.
Other requests for this document must be
referred to RADC (DCLD), GAFB, NY 13441.

Rome Air Development Center
Air Force Systems Command
Griffiss Air Force Base, New York 13441

AD B 000632

AIR FORCE COMMUNICATIONS SERVICE
DIGITAL TRANSMISSION STUDY

Volume I
Test Results

Appendix
Computer Analysis
of
Isochronous Distortion Data

R.M. Houston
Computer Sciences Corporation



Distribution limited to US Gov't agencies
only; test and evaluation; October 1974.
Other requests for this document must be
referred to RADC (DCLD), GAFB, NY 13441.

APPENDIX I

COMPUTER ANALYSIS OF ISOCRONOUS DISTORTION DATA

This appendix presents the results of the computer analysis of the data resulting from 174 isochronous distortion tests. In excess of 1,000 isochronous distortion tests were run during the course of the measurement program. However, the time required to reduce all the data through use of the computer was prohibitive. In addition, the test results presented here provide more than sufficient information concerning the statistical trends of isochronous distortion.

As discussed in Section 5, a high speed paper tape punch was used to reduce the results of each pulse width measurement. A computer program then read the paper tapes and transferred the information to punched cards. A second program read the information from the punched cards and accomplished the data reduction. An IBM 1130 computer was used for both purposes.

The first line of the computer print-out identifies each test by number, for reference purposes in Section 5 and as a means of identifying the associated histogram. Also shown is the width of the data interval in seconds. The beginning of the paper tape associated with each test run contained 20 clock period measurements, which were averaged to obtain the unit interval.

The second line of the print-out contains pertinent information concerning the test setup. The driver/receiver, signal format, and type of test are first identified. "PROT" indicates that line protectors were utilized. "NO PROT" indicates that protectors were not utilized. "TERM" indicates that the cable was terminated in 100 ohms at the receiver input. "BM" indicates that the cable was back-matched (50 ohms in each side of the cable) at the driver output. "BAL POT" indicates that the driver output and receiver input balancing components were used. "NO BAL POT" indicates that the balancing components were not used. Cable length, cable type (shielded, inside plant - IP, unshielded, outside plant - OP), and nominal transmission rate are identified at the end of the second line of the print-out. "ONES" indicates that the pulse width measurements were made between rising and falling transitions. "ZEROS" indicates that the measurements were made between falling and rising transitions.

The data were reduced in both absolute time and percent of the unit interval. The mean, standard deviation, minimum, maximum, and average were calculated in both cases. The mean is for the values as calculated, whether positive or negative. The average is for absolute values.

The histograms were generated by sorting, in descending order, the absolute values of the calculated percentage errors, and plotting. The plots show the number of pulse width measurements, from a total of 500, that exceeded some given distortion level in percent of the unit interval. For example, in test number 130, 120 of the 500 measurements had distortion levels exceeding approximately 17 percent.

The computer program was set-up so that the output could be obtained in a variety of forms. The complete program, in addition to the output discussed above, generated a complete listing giving each pulse measurement in seconds, time error in percent of the unit interval, and time error in seconds. Also, in addition to the histogram discussed above, a plot showing percent distortion for each of the 500 measurements could be generated. Since the complete output required considerable computer time, the capability was provided in the program to suppress any portion of the output not desired. The complete computer output was generated for test number 75, as an example of the total capability of the program.

On the histograms, the first digit of the test number identifies the portion of the program used to reduce the data and should, for purposes of relating the histogram to the appropriate portion of the computer print-out, be ignored. The digit in question was an input to the program required to identify the waveform type.

Data resulting from the use of three transmitted waveforms were reduced: bi-phase, NRZ, and RZ.

For the bi-phase data, the program first determined if the measurement corresponded to a half or a full unit interval pulse. The program then subtracted a half or a full unit interval to determine the magnitude of the pulse width error. The result was divided by the unit interval and multiplied by 100 to obtain the error in percent.

For NRZ data, the program subtracted whole unit intervals from the measurement value until the remainder was less than one unit interval. If the remainder was greater than a half unit interval, the error was assumed to be negative and one additional unit

interval was subtracted to obtain the error. If the remainder was equal to or less than a half unit interval, the error was assumed to be positive and represented by the remainder. The pulse width error was divided by the unit interval and multiplied by 100 to obtain the error in percent.

For RZ data, all measurements should have been a half unit interval. Therefore, to obtain the pulse width error, it was only necessary to subtract a half unit interval from each measurement value. The result was divided by the unit interval and multiplied by 100 to obtain the error in percent.

TEST NO. 0001 UNIT INTERVAL (T) = 0.655199E-07
BIPHASE GENERATOR 15 MBPS ONES ISO DIST

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.569303E-08	0.225797E-06	-0.71196E-08	-0.305998E-08	0.569303E-08
PCT ERROR	-0.868896E 01	0.344632E 01	-0.139193E 02	-0.467030E 01	0.868896E 01

TEST NO. 0002 UNIT INTERVAL (T) = 0.662099E-07
BIPHASE GENERATOR 15 MBPS ZEROS ISO DIST

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	0.554514E-08	0.252248E-08	0.239501E-08	0.979005E-08	0.554514E-08
PCT ERROR	0.837509E 01	0.380982E 01	0.361731E 01	0.147863E 02	0.837509E 01

TEST NO. 0003 UNIT INTERVAL (T) = 0.785799E-07
BIPHASE GENERATOR 10 MBPS ONES ISO DIST

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.650735E-08	0.192573E-08	-0.747996E-08	-0.348998E-08	0.650735E-08
PCT ERROR	-0.660106E 01	0.195307E 01	-0.961652E 01	-0.354025E 01	0.660106E 01

TEST NO. 0004 UNIT INTERVAL (T) = 0.982499E-07
BIPHASE GENERATOR 10 MBPS ZEROS ISO DIST

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	0.574877E-08	0.206561E-08	0.337502E-08	0.995006E-08	0.574877E-08
PCT ERROR	0.585120E 01	0.210229E 01	0.343514E 01	0.910949E 01	0.585120E 01

TEST NO. 0005 UNIT INTERVAL (T) = 0.200089E-06
BIPHASE GENERATOR 5 MBPS ONES ISO DIST

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.725414E-08	0.173428E-08	-0.958988E-08	-0.454494E-08	0.725414E-08
PCT ERROR	-0.362543E 01	0.866801E 00	-0.479278E 01	-0.227145E 01	0.362543E 01

TEST NO. 0006 UNIT INTERVAL (T) = 0.200099E-06
BIPHASE GENERATOR 5 MBPS ZEROS ISO DIST

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	0.610332E-08	0.215352E-08	0.295006E-08	0.930012E-08	0.610332E-08
	0.305014E 01	0.107620E 01	0.147429E 01	0.464774E 01	0.305014E 01

TEST NO. 0007 UNIT INTERVAL (T) = 0.332559E-06
BIPHASE GENERATOR 3 MBPS ONES ISO DIST

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.708944E-08	0.162078E-08	-0.945988E-08	-0.527993E-08	0.708944E-08
	-0.213178E 01	0.487328E 00	-0.284456E 01	-0.158766E 01	0.213178E 01

TEST NO. 0008 UNIT INTERVAL (T) = 0.332469E-06
BIPHASE GENERATOR 3 MBPS ZEROS ISO DIST

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	0.596491E-08	0.199670E-08	0.386504E-08	0.873012E-08	0.596491E-08
	0.179411E 01	0.600610E 00	0.116252E 01	0.262584E 01	0.179411E 01

TEST NO. 0009 UNIT INTERVAL (T) = 0.100024E-05
BIPHASE GENERATOR 1 MBPS ONES ISO DIST

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.693581E-08	0.164182E-08	-0.934937E-08	-0.492468E-08	0.693581E-08
	-0.693399E 00	0.164182E 00	-0.934705E 00	-0.492346E 00	0.693399E 00

TEST NO. 0010 UNIT INTERVAL (T) = 0.100009E-05
BIPHASE GENERATOR 1 MBPS ZEROS ISO DIST

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	0.596203E-08	0.199892E-08	0.375030E-08	0.870045E-08	0.596203E-08
	0.596137E 00	0.199898E 00	0.374992E 00	0.869959E 00	0.596137E 00

TEST NO. 0011 UNIT INTERVAL (T) = 0.199969E-05
 BIPHASE GENERATOR 500 KBPS ONES ISO DIST

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.706838E-08	0.167510E-08	-0.939917E-08	-0.504951E-08	0.706838E-08
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.353465E 00	0.838014E-01	-0.470029E 00	-0.252513E 00	0.353465E 00

TEST NO. 0012 UNIT INTERVAL (T) = 0.199908E-05
 BIPHASE GENERATOR 500 KBPS ZEROS ISO DIST

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	0.131875E-09	0.501874E-09	-0.788986E-09	0.101090E-08	0.415339E-09
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	0.659668E-02	0.251050E-01	-0.394673E-01	0.505682E-01	0.207760E-01

TEST NO. 0013 UNIT INTERVAL (T) = 0.667299E-07
 NRZ GENERATOR 15 MBPS ONES ISO DIST

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.154313E-08	0.607192E-09	-0.242970E-08	0.126021E-08	0.157539E-08
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.231249E 01	0.909956E 00	-0.364172E 01	0.188553E 01	0.236081E 01

TEST NO. 0014 UNIT INTERVAL (T) = 0.495849E-07
 NRZ GENERATOR 10 MBPS ONES ISO DIST

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.197517E-08	0.437013E-09	-0.274946E-08	0.180051E-09	0.197589E-08
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.178329E 01	0.438919E 00	-0.240144E 01	0.180792E 00	0.198401E 01

TEST NO. 0015 UNIT INTERVAL (T) = 0.199729E-06
 NRZ GENERATOR 5 MBPS ONES ISO DIST

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.143474E-08	0.726888E-09	-0.242945E-08	0.270017E-08	0.151556E-08
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.718331E 00	0.363952E 00	-0.121657E 01	0.135191E 01	0.758797E 00

TEST NO. 0016 UNIT INTERVAL (T) = 0.333269E-06
NRZ GENERATOR 3 MBPS ONES ISO DIST

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.107567E-08	0.644707E-09	-0.206983E-08	0.270165E-08	0.116692E-08
PCT ERROR	-0.322758E 00	0.193457E 00	-0.521070E 00	0.810650E 00	0.350136E 00

TEST NO. 0017 UNIT INTERVAL (T) = 0.999669E-06
NRZ GENERATOR 1 MBPS ONES ISO DIST

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.163031E-08	0.530839E-09	-0.308591E-08	0.904037E-09	0.164722E-08
PCT ERROR	-0.163082E 00	0.531095E-01	-0.308633E 00	0.904336E-01	0.164774E 00

TEST NO. 0018 UNIT INTERVAL (T) = 0.199979E-05
NRZ GENERATOR 500 KBPS ONES ISO DIST

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.451910E-09	0.742682E-09	-0.174898E-08	0.340514E-08	0.101149E-08
PCT ERROR	-0.425989E-01	0.371386E-01	-0.899530E-01	0.170274E 00	0.505785E-01

TEST NO. 0019 UNIT INTERVAL (T) = 0.667299E-07
NRZ GENERATOR 15 MBPS ONES ISO DIST

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	0.508210E-08	0.335842E-09	0.443501E-08	0.563502E-08	0.508210E-08
PCT ERROR	0.761592E 01	0.503171E 00	0.664621E 01	0.844431E 01	0.761592E 01

TEST NO. 0020 UNIT INTERVAL (T) = 0.999399E-07
NRZ GENERATOR 10 MBPS ONES ISO DIST

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	0.332676E-08	0.299927E-09	0.233001E-08	0.403002E-08	0.332676E-08
PCT ERROR	0.332874E 01	0.300258E 00	0.233141E 01	0.403245E 01	0.332874E 01

TEST NO. 0021 UNIT INTERVAL (T) = 0.199599E-06
RZ GENERATOR 5 MBPS ONES ISO DIST

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	0.233480E-08	0.420361E-09	0.150004E-08	0.320005E-08	0.233480E-08
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	0.116973E 01	0.210602E 00	0.751524E 00	0.160323E 01	0.116973E 01

TEST NO. 0022 UNIT INTERVAL (T) = 0.333109E-06
RZ GENERATOR 3 MBPS ONES ISO DIST

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	0.224869E-08	0.439414E-09	0.154511E-08	0.314511E-08	0.224869E-08
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	0.675047E 00	0.131682E 00	0.463846E 00	0.944168E 00	0.675047E 00

TEST NO. 0023 UNIT INTERVAL (T) = 0.999149E-06
RZ GENERATOR 1 MBPS ONES ISO DIST

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	0.187907E-08	0.762369E-09	0.325297E-09	0.325297E-08	0.187907E-08
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	0.188063E 00	0.763119E-01	0.926045E-01	0.322804E 00	0.188063E 00

TEST NO. 0024 UNIT INTERVAL (T) = 0.200109E-05
RZ GENERATOR 500 KBPS ONES ISO DIST

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	0.175031E-08	0.803611E-09	0.155523E-09	0.325530E-08	0.175031E-08
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	0.874659E-01	0.401628E-01	0.777194E-02	0.162676E 00	0.874659E-01

TEST NO. 0025 UNIT INTERVAL (T) = 0.999179E-06
FAIR 4621/4620 BIPHASE ISO DIST NU PROT 8M ISO BAL PDI 1000 FT 24 GA IP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.387578E-07	0.145765E-06	-0.303089E-06	0.198910E-06	0.122207E-06
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.387897E 01	0.145885E 02	-0.303338E 02	0.199073E 02	0.122307E 02

TEST NO. 0026 UNIT INTERVAL (T) = 0.133364E-05
 FAIR 9621/9620 BIPHASE ISO DIST NC PROT RM NO BAL POT 1000 FT 24 GA IP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX
	-0.254992E-07	0.160898E-06	-0.329624E-06	0.197150E-06
PCT ERROR	MEAN	SD	MIN	MAX
	-0.191199E 01	0.120645E 02	-0.247159E 02	0.147827E 02

AVER OF ABS
 0.132693E-06
 AVER OF ABS
 0.994964E 01

TEST NO. 0027 UNIT INTERVAL (T) = 0.199956E-05
 FAIR 9621/9620 BIPHASE ISO DIST NC PROT RM NO BAL POT 1000 FT 24 GA IP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX
	-0.535533E-07	0.160869E-06	-0.351784E-06	0.199530E-06
PCT ERROR	MEAN	SD	MIN	MAX
	-0.267823E 01	0.804519E 01	-0.175930E 02	0.997869E 01

AVER OF ABS
 0.133576E-06
 AVER OF ABS
 0.668027E 01

TEST NO. 0028 UNIT INTERVAL (T) = 0.430027E-05
 FAIR 9621/9620 BIPHASE ISO DIST NC PROT RM NO BAL POT 1000 FT 24 GA IP 250 KBPS

TIME ERROR	MEAN	SD	MIN	MAX
	-0.628763E-07	0.162560E-06	-0.355738E-06	0.218961E-06
PCT ERROR	MEAN	SD	MIN	MAX
	-0.157179E 01	0.406373E 01	-0.889264E 01	0.547365E 01

AVER OF ABS
 0.139139E-06
 AVER OF ABS
 0.347825E 01

TEST NO. 0029 UNIT INTERVAL (T) = 0.999737E-05
 FAIR 9621/9620 BIPHASE ISO DIST NC PROT RM NO BAL POT 1000 FT 24 GA IP 100 KBPS

TIME ERROR	MEAN	SD	MIN	MAX
	-0.483483E-07	0.187815E-06	-0.412436E-06	0.251924E-06
PCT ERROR	MEAN	SD	MIN	MAX
	-0.445597E 00	0.187861E 01	-0.412566E 01	0.251985E 01

AVER OF ABS
 0.139041E-06
 AVER OF ABS
 0.139074E 01

TEST NO. 0030 UNIT INTERVAL (T) = 0.998979E-06
 FAIR 9621/9620 BIPHASE ISO DIST NC PROT RM NO BAL POT 1000 FT 22 GA IP 1 KBPS

TIME ERROR	MEAN	SD	MIN	MAX
	-0.365091E-07	0.125108E-06	-0.270899E-06	0.156210E-06
PCT ERROR	MEAN	SD	MIN	MAX
	-0.365465E 01	0.125236E 02	-0.271166E 02	0.156369E 02

AVER OF ABS
 0.102435E-06
 AVER OF ABS
 0.102540E 02

TEST NO. 0031 UNIT INTERVAL (T) = 0.13337E-05
 FAIR 9621/9620 BIPHASE ISO DIST NO PROT RM NO HAL POT 1000 FT 22 GA IP 750 KRPS

TIME ERROR	MEAN	SD	MIN	MAX
	-0.398082E-07	0.108740E-06	-0.246589E-06	0.127220E-06
PCT ERROR	MEAN	SD	MIN	MAX
	-0.298551E 01	0.815525E 01	-0.184935E 02	0.954121E 01

AVER OF ABS
 0.909168E-07
 AVER OF ABS
 0.681853E 01

TEST NO. 0032 UNIT INTERVAL (T) = 0.200208E-05
 FAIR 9621/9620 BIPHASE ISO DIST NC PROT RM NO HAL POT 1000 FT 22 GA IP 500 KRPS

TIME ERROR	MEAN	SD	MIN	MAX
	-0.217554E-07	0.876742E-07	-0.217944E-06	0.104710E-06
PCT ERROR	MEAN	SD	MIN	MAX
	-0.108663E 01	0.437914E 01	-0.108938E 02	0.523006E 01

AVER OF ABS
 0.679953E-07
 AVER OF ABS
 0.339621E 01

TEST NO. 0033 UNIT INTERVAL (T) = 0.400147E-05
 FAIR 9621/9620 BIPHASE ISO DIST NO PROT RM NO HAL POT 1000 FT 22 GA IP 250 KRPS

TIME ERROR	MEAN	SD	MIN	MAX
	-0.420833E-07	0.850877E-07	-0.184438E-06	0.135560E-06
PCT ERROR	MEAN	SD	MIN	MAX
	-0.105169E 01	0.212641E 01	-0.460927E 01	0.336776E 01

AVER OF ABS
 0.775341E-07
 AVER OF ABS
 0.143763E 01

TEST NO. 0034 UNIT INTERVAL (T) = 0.100001E-04
 FAIR 9621/9620 BIPHASE ISO DIST NC PROT RM NO HAL POT 1000 FT 22 GA IP 100 KRPS

TIME ERROR	MEAN	SD	MIN	MAX
	-0.354689E-07	0.117299E-06	-0.258944E-06	0.155732E-06
PCT ERROR	MEAN	SD	MIN	MAX
	-0.354679E 00	0.117297E 01	-0.258979E 01	0.155730E 01

AVER OF ABS
 0.859672E-07
 AVER OF ABS
 0.859653E 00

TEST NO. 0035 UNIT INTERVAL (T) = 0.333059E-06
 FAIR 9621/9620 BIPHASE ISO DIST NC PROT RM NO HAL POT 1000 FT 24 GA CP 3 KRPS

TIME ERROR	MEAN	SD	MIN	MAX
	-0.469904E-08	0.304663E-07	-0.632299E-07	0.395701E-07
PCT ERROR	MEAN	SD	MIN	MAX
	-0.141086E 01	0.914137E 01	-0.139445E 02	0.118807E 02

AVER OF ABS
 0.262086E-07
 AVER OF ABS
 0.786905E 01

TEST NO. 0036 UNIT INTERVAL (T) = 0.499879E-06
FAIR 9621/9620 BIPHAISE ISO DIST NO PROT BM NO BAL POT 1000 FT 24 GA CP 2 MRPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.166362E-07	0.243229E-07	-0.613398E-07	0.203601E-07	0.235649E-07
PCT ERROR	-0.332803E 01	0.486574E 01	-0.122709E 02	0.407300E 01	0.471412E 01

TEST NO. 0037 UNIT INTERVAL (T) = 0.999669E-06
FAIR 9621/9620 BIPHAISE ISO DIST NO PROT BM NO BAL POT 1000 FT 24 GA CP 1 MRPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.137490E-07	0.217201E-07	-0.574347E-07	0.216305E-07	0.194820E-07
PCT ERROR	-0.137535E 01	0.217274E 01	-0.574537E 01	0.216376E 01	0.194884E 01

TEST NO. 0038 UNIT INTERVAL (T) = 0.133354E-05
FAIR 9621/9620 BIPHAISE ISO DIST NO PROT BM NO BAL POT 1000 FT 24 GA CP 750 KBPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.139416E-07	0.202869E-07	-0.564748E-07	0.165503E-07	0.180889E-07
PCT ERROR	-0.104544E 01	0.152127E 01	-0.423492E 01	0.124107E 01	0.135644E 01

TEST NO. 0039 UNIT INTERVAL (T) = 0.199975E-05
FAIR 9621/9620 BIPHAISE ISO DIST NO PROT BM NO BAL POT 1000 FT 24 GA CP 500 KBPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.209795E-07	0.202546E-07	-0.545794E-07	0.122404E-07	0.237812E-07
PCT ERROR	-0.104910E 01	0.101246E 01	-0.272930E 01	0.612095E 00	0.116919E 01

TEST NO. 0040 UNIT INTERVAL (T) = 0.333299E-06
FAIR 9621/9620 BIPHAISE ISO DIST NO PROT BM NO BAL POT 1000 FT 22 GA CP 3 MBPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	0.264386E-03	0.429570E-07	-0.831798E-07	0.778500E-07	0.360900E-07
PCT ERROR	0.793237E 00	0.128884E 02	-0.247624E 02	0.233573E 02	0.108280E 02

TEST NO. 0041 UNIT INTERVAL (T) = 0.499819E-06
FAIR 9621/9620 BIPHASE ISO DIST NO PROT BM NO BAL POT 1000 FT 22 GA CP 2 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.163540E-07	0.302589E-07	-0.713098E-07	0.347901E-07	0.283480E-07
	-0.327198E 01	0.605396E 01	-0.142671E 02	0.696053E 01	0.567164E 01

TEST NO. 0042 UNIT INTERVAL (T) = 0.999219E-06
FAIR 9621/9620 BIPHASE ISO DIST NO PROT BM NO BAL POT 1000 FT 22 GA CP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.152669E-07	0.301674E-07	-0.781096E-07	0.319807E-07	0.272624E-07
	-0.152787E 01	0.301916E 01	-0.781706E 01	0.320057E 01	0.272836E 01

TEST NO. 0043 UNIT INTERVAL (T) = 0.133313E-05
FAIR 9621/9620 BIPHASE ISO DIST NO PROT BM NO BAL POT 1000 FT 22 GA CP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.130324E-07	0.304180E-07	-0.911998E-07	0.297004E-07	0.244984E-07
	-0.977526E 00	0.228158E 01	-0.609099E 01	0.222775E 01	0.193756E 01

TEST NO. 0044 UNIT INTERVAL (T) = 0.200031E-05
FAIR 9621/9620 BIPHASE ISO DIST NO PROT BM NO BAL POT 1000 FT 22 GA CP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.226705E-07	0.326755E-07	-0.410596E-07	0.417808E-07	0.324071E-07
	-0.113334E 01	0.163252E 01	-0.405233E 01	0.20870E 01	0.162009E 01

TEST NO. 0045 UNIT INTERVAL (T) = 0.235709E-06
FAIR 9621/9620 BIPHASE ISO DIST NO PROT BM NO BAL POT 1000 FT 19 GA CP 3.5 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.665773E-08	0.295417E-07	-0.652349E-07	0.416450E-07	0.248408E-07
	-0.233022E 01	0.103397E 02	-0.228395E 02	0.145759E 02	0.869444E 01

TEST NO. 0046 UNIT INTERVAL (T) = 0.50029E-06
 FAIR 9621/9620 BIPHASE ISO DIST NO PROT BM NO BAL POT 1000 FT 19 GA CP 2 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.157170E-07	0.165387E-07	-0.475149E-07	0.116850E-07	0.178097E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.314320E 01	0.330756E 01	-0.950241E 01	0.233687E 01	0.356173E 01

TEST NO. 0047 UNIT INTERVAL (T) = 0.100267E-05
 FAIR 9621/9620 BIPHASE ISO DIST NO PROT BM NO BAL POT 1000 FT 19 GA CP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.137859E-07	0.126161E-07	-0.404398E-07	0.412023E-08	0.143660E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.137489E 01	0.125825E 01	-0.403317E 01	0.410922E 00	0.143275E 01

TEST NO. 0048 UNIT INTERVAL (T) = 0.133294E-05
 FAIR 9621/9620 BIPHASE ISO DIST NC PROT RM NO BAL POT 1000 FT 19 GA CP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.162259E-07	0.136951E-07	-0.390747E-07	0.742534E-08	0.176514E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.121728E 01	0.102743E 01	-0.293145E 01	0.557061E 00	0.132423E 01

TEST NO. 0049 UNIT INTERVAL (T) = 0.199980E-05
 FAIR 9621/9620 BIPHASE ISO DIST NO PROT RM NO BAL POT 1000 FT 19 GA CP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.189136E-07	0.166616E-07	-0.458044E-07	0.114905E-07	0.208658E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.945767E 00	0.833169E 00	-0.229044E 01	0.574582E 00	0.104338E 01

TEST NO. 0050 UNIT INTERVAL (T) = 0.100013E-05
 FAIR 9621/9620 BIPHASE ISO DIST NO PROT TERM NC 3AL POT 1000 FT 24 GA IP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.550464E-07	0.135959E-06	-0.306609E-06	0.147130E-06	0.114799E-06
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.550386E 01	0.135940E 02	-0.306626E 02	0.147109E 02	0.114783E 02

TEST NO. 0051 UNIT INTERVAL (T) = 0.133328E-05
FAIR 9621/9620 BIPHASE ISO DIST NO PRO TERM NO BAL POT 1000 FT 24 GA IP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
-0.373232E-07	0.124674E-06		-0.281744E-06	0.137710E-06	0.100835E-06
-0.279932E 01	0.935092E 01		-0.211315E 02	0.103286E 02	0.756290E 01

TEST NO. 0052 UNIT INTERVAL (T) = 0.200013E-05
FAIR 9621/9620 BIPHASE ISO DIST NO PRO TERM NO BAL POT 1000 FT 24 GA IP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
-0.564482E-07	0.105070E-06		-0.234969E-06	0.122760E-06	0.930195E-07
-0.282220E 01	0.525314E 01		-0.117476E 02	0.613761E 01	0.465065E 01

TEST NO. 0053 UNIT INTERVAL (T) = 0.399871E-05
FAIR 9621/9620 BIPHASE ISO DIST NO PRO TERM NO BAL POT 1000 FT 24 GA IP 250 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
-0.483829E-07	0.457047E-07		-0.117038E-06	0.487816E-07	0.589858E-07
-0.120945E 01	0.114299E 01		-0.242740E 01	0.121993E 01	0.147510E 01

TEST NO. 0054 UNIT INTERVAL (T) = 0.100011E-04
FAIR 9621/9620 BIPHASE ISO DIST NO PRO TERM NO BAL POT 1000 FT 24 GA IP 100 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
-0.488191E-07	0.138626E-07		-0.790169E-07	-0.275586E-07	0.488191E-07
-0.488131E 00	0.138632E 00		-0.790001E 00	-0.275555E 00	0.488131E 00

TEST NO. 0055 UNIT INTERVAL (T) = 0.999429E-06
FAIR 9621/9620 BIPHASE ISO DIST NO PRO TERM NO BAL POT 1000 FT 22 GA IP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
-0.471111E-07	0.120364E-06		-0.274414E-06	0.129570E-06	0.987161E-07
-0.471379E 01	0.120433E 02		-0.274571E 02	0.129644E 02	0.987725E 01

TEST NO. 0056 UNIT INTERVAL (T) = 0.133316E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NO PRO TERM NO HAL POT 1000 FT 22 GA IP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.457675E-07	0.991877E-07	-0.226484E-06	0.114730E-06	0.826063E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.343298E 01	0.744000E 01	-0.169884E 02	0.860564E 01	0.619623E 01

TEST NO. 0057 UNIT INTERVAL (T) = 0.199986E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NO PRO TERM NO HAL POT 1000 FT 22 GA IP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.277587E-07	0.657085E-07	-0.168834E-06	0.870309E-07	0.533509E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.138802E 01	0.328564E 01	-0.844227E 01	0.435183E 01	0.266771E 01

TEST NO. 0058 UNIT INTERVAL (T) = 0.339888E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NO PRO TERM NO HAL POT 1000 FT 22 GA IP 250 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.331581E-07	0.285757E-07	-0.700447E-07	0.324107E-07	0.393966E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.829174E 00	0.714600E 00	-0.175100E 01	0.810494E 00	0.985185E 00

TEST NO. 0059 UNIT INTERVAL (T) = 0.999359E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NO PRO TERM NO HAL POT 1000 FT 22 GA IP 100 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.318581E-07	0.172401E-07	-0.684976E-07	-0.459840E-08	0.318581E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.318779E 00	0.172522E 00	-0.685415E 00	-0.460135E-01	0.318779E 00

TEST NO. 0060 UNIT INTERVAL (T) = 0.333289E-06
 FAIR 9621/9620 BIPHAISE ISO DIST NO PRO TERM NO HAL POT 1000 FT 24 GA UP 3 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.116770E-07	0.204462E-07	-0.536449E-07	0.158550E-07	0.183194E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.350355E 01	0.613468E 01	-0.160955E 02	0.475713E 01	0.549654E 01

TEST NO. 0061 UNIT INTERVAL (T) = 0.499569E-06
 FAIR 9621/9620 BIPHAISE ISO DIST NC PRO TERM NO BAL POT 1000 FT 24 GA OP 2 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.172413E-07	0.159117E-07	-0.477847E-07	0.863042E-08	0.185952E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.345122E 01	0.318509E 01	-0.956518E 01	0.172757E 01	0.372224E 01

TEST NO. 0062 UNIT INTERVAL (T) = 0.100001E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NC PRO TERM NO BAL POT 1000 FT 24 GA OP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.143337E-07	0.111263E-07	-0.379096E-07	0.598038E-08	0.147588E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.143333E 01	0.111263E 01	-0.379096E 01	0.598026E 00	0.147584E 01

TEST NO. 0063 UNIT INTERVAL (T) = 0.133336E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NC PRO TERM NO BAL POT 1000 FT 24 GA UP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.152968E-07	0.839688E-08	-0.328847E-07	0.430418E-09	0.153021E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.114722E 01	0.629763E 00	-0.246628E 01	0.322805E-01	0.114762E 01

TEST NO. 0064 UNIT INTERVAL (T) = 0.199939E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NC PRO TERM NO BAL POT 1000 FT 24 GA OP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.143579E-07	0.345189E-08	-0.218994E-07	-0.759863E-08	0.143579E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.718103E 00	0.172683E 00	-0.109530E 01	-0.380055E 00	0.718103E 00

TEST NO. 0065 UNIT INTERVAL (T) = 0.333409E-06
 FAIR 9621/9620 BIPHAISE ISO DIST NC PRO TERM NO BAL POT 1000 FT 22 GA OP 3 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.844042E-08	0.399830E-07	-0.893049E-07	0.576950E-07	0.333747E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.253154E 01	0.111921E 02	-0.267853E 02	0.173045E 02	0.100100E 02

TEST NO. 0066 UNIT INTERVAL (T) = 0.500259E-06
 FAIR 9621/9620 BIPHAISE ISO DIST NO PRO TERM NO BAL POT 1000 FT 22 GA OP 2 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.210456E-07	0.300703E-07	-0.757298E-07	0.287403E-07	0.289328E-07
PCT ERROR	-0.420695E 01	0.601095E 01	-0.151381E 02	0.574509E 01	0.578353E 01

TEST NO. 0067 UNIT INTERVAL (T) = 0.999279E-06
 FAIR 9621/9620 BIPHAISE ISO DIST NO PRO TERM NO BAL POT 1000 FT 22 GA OP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.179834E-07	0.230281E-07	-0.624396E-07	0.149207E-07	0.210509E-07
PCT ERROR	-0.179963E 01	0.230447E 01	-0.624847E 01	0.149314E 01	0.210660E 01

TEST NO. 0068 UNIT INTERVAL (T) = 0.133345E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NO PRO TERM NO HAL POT 1000 FT 22 GA OP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.167695E-07	0.187087E-07	-0.567297E-07	0.204404E-07	0.209091E-07
PCT ERROR	-0.125758E 01	0.140303E 01	-0.425432E 01	0.153288E 01	0.156802E 01

TEST NO. 0069 UNIT INTERVAL (T) = 0.200001E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NC PRC TERM NO BAL POT 1000 FT 22 GA OP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.177387E-07	0.997124E-08	-0.393095E-07	-0.291902E-08	0.177387E-07
PCT ERROR	-0.486925E 00	0.498566E 00	-0.196545E 01	-0.145949E 00	0.886925E 00

TEST NO. 0070 UNIT INTERVAL (T) = 0.285639E-06
 FAIR 9621/9620 BIPHAISE ISO DIST NO PRO TERM NO HAL POT 1000 FT 19 GA OP 3.5 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.115782E-07	0.198021E-07	-0.523199E-07	0.152800E-07	0.180519E-07
PCT ERROR	-0.405344E 01	0.693257E 01	-0.184917E 02	0.534942E 01	0.631981E 01

TEST NO. 0071 UNIT INTERVAL (T) = 0.499829E-06
 FAIR 9621/9620 BIPHAISE ISO DIST NO PRO TERM NO BAL PCT 1000 FT 19 GA OP 2 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.170063E-07	0.130873E-07	-0.410148E-07	0.317027E-08	0.172045E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.340242E 01	0.261837E 01	-0.820576E 01	0.634270E 00	0.344208E 01

TEST NO. 0072 UNIT INTERVAL (T) = 0.999409E-06
 FAIR 9621/9620 BIPHAISE ISO DIST NO PRO TERM NO BAL PCT 1000 FT 19 GA OP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.140091E-07	0.921887E-08	-0.335046E-07	0.289060E-08	0.142598E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.140173E 01	0.922450E 00	-0.335244E 01	0.289231E 00	0.142681E 01

TEST NO. 0073 UNIT INTERVAL (T) = 0.133339E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NO PRO TERM NO HAL PCT 1000 FT 19 GA OP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.167315E-07	0.805337E-08	-0.308997E-07	-0.379975E-08	0.167315E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.125479E 01	0.603996E 00	-0.231736F 01	-0.284967E 00	0.125479E 01

TEST NO. 0074 UNIT INTERVAL (T) = 0.199994E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NO PRO TERM NO BAL PCT 1000 FT 19 GA OP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.166197E-07	0.741659E-08	-0.305744E-07	-0.384898E-08	0.166197E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.831002E 00	0.370855E 00	-0.152876E 01	-0.192454E 00	0.831002E 00

TEST NO. 0075 UNIT INTERVAL (T) = 0.999259E-06
 FAIR 9621/9620 BIPHAISE ISO DIST NO PRO TERM BAL PCT 1000 FT 24 GA IP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.728028E-07	0.141653E-06	-0.333129E-06	0.138970E-06	0.125476E-06
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.728569E 01	0.141758E 02	-0.333376E 02	0.139073E 02	0.125569E 02

TEST NO. 0076 UNIT INTERVAL ITI = 0.133331E-05
FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL POT 1000 FT 24 GA IP 750 KBPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.620626E-07	0.136325E-06	-0.306059E-06	0.124680E-06	0.117001E-06
PCT ERROR	-0.465473E 01	0.102245E 02	-0.229547E 02	0.935114E 01	0.877519E 01

TEST NO. 0077 UNIT INTERVAL ITI = 0.200028E-05
FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL POT 1000 FT 24 GA IP 500 KBPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.717238E-07	0.111369E-06	-0.259644E-06	0.113210E-06	0.104396E-06
PCT ERROR	-0.358567E 01	0.556767E 01	-0.129803E 02	0.565971E 01	0.521905E 01

TEST NO. 0078 UNIT INTERVAL ITI = 0.400290E-05
FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL POT 1000 FT 24 GA IP 250 KBPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.639672E-07	0.520478E-07	-0.144754E-06	0.431919E-07	0.722321E-07
PCT ERROR	-0.159801E 01	0.130025E 01	-0.361622E 01	0.107901E 01	0.180449E 01

TEST NO. 0079 UNIT INTERVAL ITI = 0.999337E-05
FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL POT 1000 FT 24 GA IP 100 KBPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.630367E-07	0.962457E-08	-0.851760E-07	-0.503887E-07	0.630367E-07
PCT ERROR	-0.630780E 00	0.963426E-01	-0.852324E 00	-0.504221E 00	0.630780E 00

TEST NO. 0080 UNIT INTERVAL ITI = 0.999589E-06
FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL POT 1000 FT 22 GA IP 1 MBPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.645021E-07	0.122831E-06	-0.297894E-06	0.113010E-06	0.107110E-06
PCT ERROR	-0.645285E 01	0.122882E 02	-0.298017E 02	0.113056E 02	0.107154E 02

TEST NO. 0081 UNIT INTERVAL ITI = 0.133321E-05
FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL PDT 1000 FT 22 GA IP 750 KRPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.634694E-07	0.103340E-06	-0.246609E-06	0.997804E-07	0.944816E-07
PCT ERROR	-0.476061E 01	0.775117E 01	-0.184973E 02	0.748417E 01	0.708674E 01

TEST NO. 0082 UNIT INTERVAL ITI = 0.199939E-05
FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL PDT 1000 FT 22 GA IP 500 KRPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.422471E-07	0.696685E-07	-0.189899E-06	0.741006E-07	0.602621E-07
PCT ERROR	-0.211299E 01	0.348447E 01	-0.949782E 01	0.370614E 01	0.301400E 01

TEST NO. 0083 UNIT INTERVAL ITI = 0.399847E-05
FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL PDT 1000 FT 22 GA IP 250 KRPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.480269E-07	0.324007E-07	-0.963309E-07	0.237223E-07	0.521107E-07
PCT ERROR	-0.120112E 01	0.810333E 00	-0.240999E 01	0.593284E 00	0.130325E 01

TEST NO. 0084 UNIT INTERVAL ITI = 0.999112E-05
FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL PDT 1000 FT 22 GA IP 100 KRPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.437202E-07	0.141558E-07	-0.750242E-07	-0.225627E-07	0.437202E-07
PCT ERROR	-0.437586E 00	0.141695E 00	-0.750908E 00	-0.225827E 00	0.437586E 00

TEST NO. 0085 UNIT INTERVAL ITI = 0.333409E-06
FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL PDT 1000 FT 24 GA OP 3 MRPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.213403E-07	0.203694E-07	-0.659049E-07	0.419504E-08	0.220024E-07
PCT ERROR	-0.640061E 01	0.610944E 01	-0.197669E 02	0.125822E 01	0.659920E 01

TEST NO. 0086 UNIT INTERVAL (T) = 0.499949E-06
 FAIR 9621/9620 BIPHAZE ISO DIST NO PROT TERM BAL POT 1000 FT 24 GA OP 2 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.264618E-07	0.171561E-07	-0.592748E-07	0.650175E-09	0.264660E-07
	-0.529288E 01	0.343159E 01	-0.118561E 02	0.130048E 00	0.529372E 01

TEST NO. 0087 UNIT INTERVAL (T) = 0.999609E-06
 FAIR 9621/9620 BIPHAZE ISO DIST NO PROT TERM BAL POT 1000 FT 24 GA OP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.230173E-07	0.1117844E-07	-0.474046E-07	-0.640943E-08	0.230173E-07
	-0.230262E 01	0.1117892E 01	-0.474232E 01	-0.641194E 00	0.230262E 01

TEST NO. 0088 UNIT INTERVAL (T) = 0.131282E-05
 FAIR 9621/9620 BIPHAZE ISO DIST NO PROT TERM BAL POT 1000 FT 24 GA OP 750 KRPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.239129E-07	0.960966E-08	-0.439147E-07	-0.872933E-08	0.239129E-07
	-0.179414E 01	0.721007E 00	-0.329405E 01	-0.654947E 00	0.179414E 01

TEST NO. 0089 UNIT INTERVAL (T) = 0.199997E-05
 FAIR 9621/9620 BIPHAZE ISO DIST NO PROT TERM BAL POT 1000 FT 24 GA OP 500 KRPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.247185E-07	0.430125E-08	-0.313996E-07	-0.151790E-07	0.247185E-07
	-0.123593E 01	0.215088E 00	-0.156949E 01	-0.758958E 00	0.123593E 01

TEST NO. 0090 UNIT INTERVAL (T) = 0.333099E-06
 FAIR 9621/9620 BIPHAZE ISO DIST NO PROT TERM BAL POT 1000 FT 22 GA OP 3 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.209296E-07	0.381171E-07	-0.104749E-06	0.324501E-07	0.333834E-07
	-0.628328E 01	0.114431E 02	-0.314479E 02	0.974186E 01	0.100220E 02

TEST NO. 0091 UNIT INTERVAL (T) = 0.500099E-06
 FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL POT 1000 FT 22 GA OP 2 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.308178E-07	0.298363E-07	-0.846499E-07	0.163000E-07	0.336471E-07
	-0.616230E 01	0.596609E 01	-0.169266E 02	0.325936E 01	0.672807E 01

TEST NO. 0092 UNIT INTERVAL (T) = 0.100020E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NC PROT TERM BAL POT 1000 FT 22 GA OP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.257705E-07	0.231417E-07	-0.716047E-07	0.559043E-08	0.263014E-07
	-0.257651E 01	0.231370E 01	-0.715897E 01	0.558926E 00	0.262959E 01

TEST NO. 0093 UNIT INTERVAL (T) = 0.133342E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL POT 1000 FT 22 GA OP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.256855E-07	0.195125E-07	-0.670147E-07	0.275704E-08	0.271648E-07
	-0.192627E 01	0.146333E 01	-0.502514E 01	0.567739E 00	0.203721E 01

TEST NO. 0094 UNIT INTERVAL (T) = 0.199937E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NC PROT TERM BAL POT 1000 FT 22 GA OP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.281323E-07	0.116123E-07	-0.499893E-07	-0.997897E-08	0.281323E-07
	-0.140705E 01	0.580805E 00	-0.250024E 01	-0.499103E 00	0.146705E 01

TEST NO. 0095 UNIT INTERVAL (T) = 0.285669E-06
 FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL POT 1000 FT 19 GA OP 3.5 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.220799E-07	0.200768E-07	-0.636349E-07	0.416508E-08	0.224798E-07
	-0.772920E 01	0.702793E 01	-0.222756E 02	0.145800E 01	0.786920E 01

TEST NO. 0096 UNIT INTERVAL IT1 = 0.500009E-06
 FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL POT 1000 FT 19 GA OP 2 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.245860E-07	0.131230E-07	-0.483048E-07	-0.510976E-08	0.245860E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.491711E 01	0.262457E 01	-0.966078E 01	-0.102193E 01	0.491711E 01

TEST NO. 0097 UNIT INTERVAL IT1 = 0.100004E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL POT 1000 FT 19 GA OP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.208680E-07	0.956630E-08	-0.411246E-07	-0.644945E-08	0.208680E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.208669E 01	0.956593E 00	-0.411226E 01	-0.644913E 00	0.208669E 01

TEST NO. 0098 UNIT INTERVAL IT1 = 0.133319E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NO PROT TERM BAL POT 1000 FT 19 GA OP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.238901E-07	0.880889E-08	-0.393996E-07	-0.118997E-07	0.238901E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.179193E 01	0.660734E 00	-0.295527E 01	-0.892568E 00	0.179193E 01

TEST NO. 0099 UNIT INTERVAL IT1 = 0.199992E-05
 FAIR 9621/9620 BIPHAISE ISO DIST NC PROT TERM BAL POT 1000 FT 19 GA OP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.240551E-07	0.744437E-08	-0.374643E-07	-0.130289E-07	0.240551E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.120280E 01	0.372228E 00	-0.187328E 01	-0.651471E 00	0.120280E 01

TEST NO. 0100 UNIT INTERVAL IT1 = 0.999769E-06
 FAIR 9621/9620 BIPHAISE ISO DIST PROT TERM BAL POT 1000 FT 24 GA IP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.633912E-07	0.152690E-06	-0.350134E-06	0.176415E-06	0.131389E-06
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.634058E 01	0.152725E 02	-0.350265E 02	0.176455E 02	0.131420E 02

TEST NO. 0101 UNIT INTERVAL (T) = 0.133307E-05
FAIR 9621/9620 BIPHA5E ISO DIST PROT TERM BAL POT 1000 FT 24 GA IP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
-0.540899E-07	0.155892E-06	-0.335539E-06	0.156520E-06	0.156520E-06	0.131373E-06
-0.405751E 01	0.116941E 02	-0.251702E 02	0.117412E 02	0.117412E 02	0.985490E 01

TEST NO. 0102 UNIT INTERVAL (T) = 0.200016E-05
FAIR 9621/9620 BIPHA5E ISO DIST PROT TERM BAL POT 1000 FT 24 GA IP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
-0.665261E-07	0.135980E-06	-0.310284E-06	0.150131E-06	0.150131E-06	0.118523E-06
-0.332602E 01	0.679845E 01	-0.155129E 02	0.750592E 01	0.750592E 01	0.592567E 01

TEST NO. 0103 UNIT INTERVAL (T) = 0.399496E-05
FAIR 9621/9620 BIPHA5E ISO DIST PROT TERM BAL POT 1000 FT 24 GA IP 250 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
-0.652280E-07	0.110676E-06	-0.251983E-06	0.102731E-06	0.102731E-06	0.100287E-06
-0.163274E 01	0.277040E 01	-0.630753E 01	0.257151E 01	0.257151E 01	0.251032E 01

TEST NO. 0104 UNIT INTERVAL (T) = 0.999236E-05
FAIR 9621/9620 BIPHA5E ISO DIST PROT TERM BAL POT 1000 FT 24 GA IP 100 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
-0.472031E-07	0.480546E-07	-0.139283E-06	0.335330E-07	0.335330E-07	0.547654E-07
-0.472387E 00	0.480917E 00	-0.139390E 01	0.335586E 00	0.335586E 00	0.548067E 00

TEST NO. 0105 UNIT INTERVAL (T) = 0.999639E-06
FAIR 9621/9620 BIPHA5E ISO DIST PROT TERM BAL POT 1000 FT 22 GA IP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
-0.532539E-07	0.124194E-06	-0.289219E-06	0.125680E-06	0.125680E-06	0.104703E-06
-0.532730E 01	0.124239E 02	-0.289324E 02	0.125725E 02	0.125725E 02	0.104740E 02

TEST NO. 0106 UNIT INTERVAL (T) = 0.133236E-05
 FAIR 9621/9620 BIPHASE ISO DIST PROT TERM BAL POT 1000 FT 22 GA IP 750 KBPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.529064E-07	0.106126E-06	-0.239284E-06	0.107930E-06	0.921424E-07
PCT ERROR	-0.397085E 01	0.796522E 01	-0.179593E 02	0.810065E 01	0.691568E 01

TEST NO. 0107 UNIT INTERVAL (T) = 0.199967E-05
 FAIR 9621/9620 BIPHASE ISO DIST PROT TERM HAL POT 1000 FT 22 GA IP 500 KBPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.295820E-07	0.789140E-07	-0.197139E-06	0.841209E-07	0.632233E-07
PCT ERROR	-0.147932E 01	0.394633E 01	-0.985855E 01	0.420672E 01	0.316166E 01

TEST NO. 0108 UNIT INTERVAL (T) = 0.399900E-05
 FAIR 9621/9620 BIPHASE ISO DIST PROT TERM BAL POT 1000 FT 22 GA IP 250 KBPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.450180E-07	0.583073E-07	-0.142704E-06	0.355903E-07	0.583332E-07
PCT ERROR	-0.112572E 01	0.145804E 01	-0.356849E 01	0.889979E 00	0.145868E 01

TEST NO. 0109 UNIT INTERVAL (T) = 0.100106E-04
 FAIR 9621/9620 BIPHASE ISO DIST PROT TERM BAL POT 1000 FT 22 GA IP 100 KBPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.343134E-07	0.254921E-07	-0.826321E-07	0.823638E-08	0.358759E-07
PCT ERROR	-0.342763E 00	0.254655E 00	-0.825441E 00	0.822761E-01	0.358372E 00

TEST NO. 0110 UNIT INTERVAL (T) = 0.332669E-06
 FAIR 9621/9620 BIPHASE ISO DIST PROT TERM BAL POT 1000 FT 24 GA CP 3 MBPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.166415E-07	0.221362E-07	-0.533348E-07	0.114650E-07	0.208646E-07
PCT ERROR	-0.500242E 01	0.665411E 01	-0.190383E 02	0.344638E 01	0.627190E 01

TEST NO. 0111 UNIT INTERVAL (T) = 0.499829E-06
FAIR 9621/9620 BIPHAISE ISO DIST PROT TERM 8AL POT 1000 FT 24 GA UP 2 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.231698E-07	0.194814E-07	-0.582148E-07	0.547027E-08	0.240048E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.463553E 01	0.389762E 01	-0.116469E 02	0.109442E 01	0.480259E 01

TEST NO. 0112 UNIT INTERVAL (T) = 0.100005E-05
FAIR 9621/9620 BIPHAISE ISO DIST PROT TERM 8AL POT 1000 FT 24 GA OP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.200451E-07	0.156279E-07	-0.509297E-07	-0.459522E-09	0.200451E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.200439E 01	0.156269E 01	-0.509267E 01	-0.459494E-01	0.200439E 01

TEST NO. 0113 UNIT INTERVAL (T) = 0.133162E-05
FAIR 9621/9620 BIPHAISE ISO DIST PROT TERM 8AL POT 1000 FT 24 GA OP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.207834E-07	0.138810E-07	-0.489146E-07	-0.202931E-08	0.207834E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.156075E 01	0.104242E 01	-0.367329E 01	-0.152393E 00	0.156075E 01

TEST NO. 0114 UNIT INTERVAL (T) = 0.199981E-05
FAIR 9621/9620 BIPHAISE ISO DIST PROT TERM 8AL POT 1000 FT 24 GA UP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.248127E-07	0.118328E-07	-0.439095E-07	-0.551926E-08	0.248127E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.124074E 01	0.591714E 00	-0.219567E 01	-0.275988E 00	0.124074E 01

TEST NO. 0115 UNIT INTERVAL (T) = 0.333079E-06
FAIR 9621/9620 BIPHAISE ISO DIST PROT TERM 8AL POT 1000 FT 22 GA OP 3 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.177455E-07	0.379511E-07	-0.102439E-06	0.329600E-07	0.328193E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.532769E 01	0.113940E 02	-0.307533E 02	0.989555E 01	0.985330E 01

TEST NO. 0116 UNIT INTERVAL (I) = 0.500179E-06
 FAIR 7621/9620 BIPHASE ISO DIST PRCT TERM BAL POT 1000 FT 22 GA CP 2 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.282950E-07	0.310430E-07	-0.842898E-07	0.195100E-07	0.333354E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.563697E 01	0.620637E 01	-0.169519E 02	0.390061E 01	0.666470E 01

TEST NO. 0117 UNIT INTERVAL (I) = 0.100057E-05
 FAIR 9621/9620 BIPHASE ISO DIST PRCT TERM BAL POT 1000 FT 22 GA CP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.261368E-07	0.282679E-07	-0.775898E-07	0.882028E-08	0.290738E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.261216E 01	0.282516F 01	-0.775448E 01	0.881517E 00	0.290568E 01

TEST NO. 0118 UNIT INTERVAL (I) = 0.133307E-05
 FAIR 7621/9620 BIPHASE ISO DIST PRCT TERM BAL POT 1000 FT 22 GA CP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.241975E-07	0.257763E-07	-0.772397E-07	0.114205E-07	0.256662E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.181516E 01	0.193335E 01	-0.579408E 01	0.856702E 00	0.192534E 01

TEST NO. 0119 UNIT INTERVAL (I) = 0.200424E-05
 FAIR 7621/9620 BIPHASE ISO DIST PRCT TERM BAL POT 1000 FT 22 GA CP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.310388E-07	0.243033E-07	-0.715246E-07	0.137506E-07	0.329064E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.154864E 01	0.121261E 01	-0.356864E 01	0.686075E 00	0.164183E 01

TEST NO. 0120 UNIT INTERVAL (I) = 0.285669E-06
 FAIR 7621/9620 BIPHASE ISO DIST PRCT TERM BAL POT 1000 FT 19 GA CP 3.5 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.228070E-07	0.214499E-07	-0.622349E-07	0.626509E-08	0.239189E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.798371E 01	0.750862E 01	-0.217856E 02	0.219312E 01	0.837296E 01

TEST NO. 0121 UNIT INTERVAL (I) = 0.500089E-06
 FAIR 9621/9620 BIPHASE ISO DIST PROT TERM BAL POT 1000 FT 19 GA CP 2 MRPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.225334E-07	0.149384E-07	-0.483448E-07	-0.104483E-08	0.225334E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.450587E 01	0.298715E 01	-0.066723E 01	-0.208930E 00	0.450587E 01

TEST NO. 0122 UNIT INTERVAL (I) = 0.999239E-06
 FAIR 9621/9620 BIPHASE ISO DIST PROT TERM BAL POT 1000 FT 19 GA CP 1 MRPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.193830E-07	0.1111724E-07	-0.423195E-07	-0.551961E-08	0.193830E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.193978E 01	0.1111808E 01	-0.428521E 01	-0.552381E 00	0.193978E 01

TEST NO. 0123 UNIT INTERVAL (I) = 0.133248E-05
 FAIR 9621/9620 BIPHASE ISO DIST PROT TERM BAL POT 1000 FT 19 GA CP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.222727E-07	0.108647E-07	-0.416445E-07	-0.664454E-08	0.222727E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.167151E 01	0.800376E 00	-0.312531E 01	-0.498656E 00	0.167151E 01

TEST NO. 0124 UNIT INTERVAL (I) = 0.200055E-05
 FAIR 9621/9620 BIPHASE ISO DIST PROT TERM BAL POT 1000 FT 19 GA CP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.236657E-07	0.106658E-07	-0.405796E-07	-0.767977E-08	0.236657E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.118294E 01	0.533165E 00	-0.202841E 01	-0.383881E 00	0.118294E 01

TEST NO. 0125 UNIT INTERVAL (I) = 0.999839E-06
 FAIR 9621/9620 NRZ ISO DIST NO PROT TERM BAL POT 1000 FT 24 GA IP 1 MRPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.125359E-06	0.161067E-06	-0.389399E-06	0.186002E-06	0.166203E-06
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.125379E 02	0.161093E 02	-0.389402E 02	0.186032E 02	0.166230E 02

TEST NO. 0126 UNIT INTERVAL (T) = 0.133288E-05
FAIR 9621/9620 NRZ 150 DIST NO PROT TERM BAL POT 1000 FT 24 GA 1P 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.106664E-06	0.114935E-06	-0.291459E-06	0.100431E-06	0.130306E-06
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.800253E 01	0.862302E 01	-0.218639E 02	0.753490E 01	0.977624E 01

TEST NO. 0127 UNIT INTERVAL (T) = 0.199966E-05
FAIR 9621/9620 NRZ 150 DIST NO PROT TERM BAL POT 1000 FT 24 GA 1P 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.103841E-06	0.542734E-07	-0.144268E-06	0.386171E-08	0.103889E-06
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.519290E 01	0.271416E 01	-0.921496E 01	0.193117E 00	0.519529E 01

TEST NO. 0128 UNIT INTERVAL (T) = 0.399883E-05
FAIR 9621/9620 NRZ 150 DIST NO PROT TERM BAL POT 1000 FT 24 GA 1P 250 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.957160E-07	0.102637E-07	-0.117177E-06	-0.780392E-07	0.957160E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.239358E 01	0.256730E 00	-0.293028E 01	-0.195154E 01	0.239358E 01

TEST NO. 0129 UNIT INTERVAL (T) = 0.100000E-04
FAIR 9621/9620 NRZ 150 DIST NO PROT TERM BAL POT 1000 FT 24 GA 1P 100 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.102231E-06	0.824658E-08	-0.114474E-06	-0.810105E-07	0.102231E-06
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.102229E 01	0.826098E-01	-0.114473E 01	-0.810099E 00	0.102229E 01

TEST NO. 0130 UNIT INTERVAL (T) = 0.999999E-06
FAIR 9621/9620 NRZ 150 DIST NO PROT TERM BAL POT 1000 FT 22 GA 1P 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.710942E-07	0.263654E-07	-0.238099E-06	0.106102E-06	0.973618E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.710941E 01	0.963654E 01	-0.238099E 02	0.106102E 02	0.973616E 01

TEST NO. 0131 UNIT INTERVAL (I) = 0.133308E-05
FAIR 9621/9620 NRZ ISO DIST NO PROT TERM BAL POT 1000 FT 22 GA IP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.665215E-07	0.628239E-07	-0.169009E-06	0.573318E-07	0.755172E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.499000E 01	0.471266E 01	-0.126840E 02	0.430067E 01	0.566481E 01

TEST NO. 0132 UNIT INTERVAL (I) = 0.199958E-05
FAIR 9621/9620 NRZ ISO DIST NO PROT TERM BAL POT 1000 FT 22 GA IP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.609861E-07	0.252064E-07	-0.104663E-06	0.272211E-08	0.610303E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.304991E 01	0.126063E 01	-0.523552E 01	0.136133E 00	0.305211E 01

TEST NO. 0133 UNIT INTERVAL (I) = 0.399901E-05
FAIR 9621/9620 NRZ ISO DIST NO PROT TERM BAL POT 1000 FT 22 GA IP 250 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.555248E-07	0.162861E-07	-0.871368E-07	-0.308182E-07	0.555248E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.138844E 01	0.407304E 00	-0.217895E 01	-0.770645E 00	0.138844E 01

TEST NO. 0134 UNIT INTERVAL (I) = 0.100096E-04
FAIR 9621/9620 NRZ ISO DIST NO PROT TERM BAL POT 1000 FT 22 GA IP 100 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.579848E-07	0.476383E-08	-0.605895E-07	-0.420150E-07	0.579848E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.579276E 00	0.477258E-01	-0.665251E 00	-0.419743E 00	0.579276E 00

TEST NO. 0135 UNIT INTERVAL (I) = 0.333239E-06
FAIR 9621/9620 NRZ ISO DIST NO PROT TERM BAL POT 1000 FT 24 GA UP 3 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.437256E-07	0.250348E-07	-0.929398E-07	0.590080E-08	0.438775E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.131213E 02	0.751259E 01	-0.278897E 02	0.177073E 01	0.131669E 02

TEST NO. 0136 UNIT INTERVAL (I) = 0.499999E-06
 FAIR 9621/9620 NRZ ISO DIST NO PROT TERM BAL POT 1000 FT 24 GA OP 2 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.426833E-07	0.171962E-07	-0.715836E-07	-0.106692E-07	0.426833E-07
	-0.853683E 01	0.347928E 01	-0.143182E 02	-0.213390E 01	0.853683E 01

TEST NO. 0137 UNIT INTERVAL (I) = 0.999919E-06
 FAIR 9621/9620 NRZ ISO DIST NO PROT TERM BAL POT 1000 FT 24 GA OP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.404874E-07	0.456471E-08	-0.493195E-07	-0.289392E-07	0.404874E-07
	-0.404905E 01	0.456590E 00	-0.493234E 01	-0.289415E 01	0.404905E 01

TEST NO. 0138 UNIT INTERVAL (I) = 0.133315E-05
 FAIR 9621/9620 NRZ ISO DIST NO PROT TERM BAL POT 1000 FT 24 GA OP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.400723E-07	0.206607E-08	-0.447594E-07	-0.348936E-07	0.400723E-07
	-0.300580E 01	0.155246E 00	-0.335739E 01	-0.261736E 01	0.300580E 01

TEST NO. 0139 UNIT INTERVAL (I) = 0.199977E-05
 FAIR 9621/9620 NRZ ISO DIST NO PROT TERM BAL POT 1000 FT 24 GA OP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.402670E-07	0.228864E-08	-0.458585E-07	-0.359791E-07	0.402670E-07
	-0.201355E 01	0.114825E 00	-0.229318E 01	-0.179915E 01	0.201355E 01

TEST NO. 0140 UNIT INTERVAL (I) = 0.333499E-06
 FAIR 9621/9620 NRZ ISO DIST NO PROT TERM BAL POT 1000 FT 22 GA OP 3 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
PCT ERROR	-0.477800E-07	0.497271E-07	-0.142099E-06	0.506001E-07	0.561771E-07
	-0.143268E 02	0.149106E 02	-0.426086E 02	0.151724E 02	0.168447E 02

TEST NO. 0141 UNIT INTERVAL IT) = 0.499349E-06
 FAIR 9621/9620 URZ ISD DIST NO PRCT TERM HAL POT 1000 FT 22 GA DP 2 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.460402E-07	0.355756E-07	-0.107849E-06	0.191012E-07	0.489432E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.921079E 01	0.711731E 01	-0.213705E 12	0.382139E 01	0.979270E 01

TEST NO. 0142 UNIT INTERVAL IT) = 0.999789E-06
 FAIR 9621/9620 URZ ISD DIST NO PRCT TERM HAL POT 1000 FT 22 GA DP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.422204E-07	0.134048E-07	-0.579394E-07	-0.145627E-07	0.422204E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.422291E 01	0.134080E 01	-0.576030E 01	-0.145713E 01	0.422291E 01

TEST NO. 0143 UNIT INTERVAL IT) = 0.133319E-05
 FAIR 9621/9620 URZ ISD DIST NO PRCT TERM HAL POT 1000 FT 22 GA DP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.4113365E-07	0.551675E-08	-0.524946E-07	-0.286991E-07	0.4113365E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.310053E 01	0.413899E 00	-0.596765E 01	-0.215264E 01	0.310053E 01

TEST NO. 0144 UNIT INTERVAL IT) = 0.199984E-05
 FAIR 9621/9620 URZ ISD DIST NO PRCT TERM HAL POT 1000 FT 22 GA DP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.399246E-07	0.267702E-08	-0.460435E-07	-0.327017E-07	0.399246E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.199637E 01	0.133999E 00	-0.230701E 01	-0.163521E 01	0.199637E 01

TEST NO. 0145 UNIT INTERVAL IT) = 0.295239E-06
 FAIR 9621/9620 URZ ISD DIST NO PRCT TERM HAL POT 1000 FT 19 GA DP 3.5 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.382604E-07	0.232090E-07	-0.883398E-07	0.568036E-08	0.382604E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.134134E 02	0.313667E 01	-0.309703E 02	0.199143E 01	0.135660E 02

TEST NO. 0146 UNIT INTERVAL (T) = 0.499839E-06
 FAIR 9621/9620 NRZ ISO DIST NO PROT TERM BAL POT 1000 FT 19 GA OP 2 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.370331E-07	0.165692E-07	-0.680337E-07	-0.269892E-08	0.370331E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.740901E 01	0.331491E 01	-0.136123E 02	-0.539958E 00	0.740901E 01

TEST NO. 0147 UNIT INTERVAL (T) = 0.100017E-05
 FAIR 9621/9620 NRZ ISO DIST NO PROT TERM BAL POT 1000 FT 19 GA OP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.368561E-07	0.960868E-08	-0.529794E-07	-0.193385E-07	0.368561E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.368493E 01	0.960773E 00	-0.529699E 01	-0.193351E 01	0.368493E 01

TEST NO. 0148 UNIT INTERVAL (T) = 0.133315E-05
 FAIR 9621/9620 NRZ ISO DIST NO PROT TERM BAL POT 1000 FT 19 GA OP 750 KRPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.363425E-07	0.691830E-08	-0.481593E-07	-0.198742E-07	0.363425E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.272603E 01	0.518997E 00	-0.361242E 01	-0.149076E 01	0.272603E 01

TEST NO. 0149 UNIT INTERVAL (T) = 0.199980E-05
 FAIR 9621/9620 NRZ ISO DIST NO PROT TERM BAL POT 1000 FT 19 GA OP 500 KRPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.374644E-07	0.268916E-08	-0.439095E-07	-0.322270E-07	0.374644E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.187338E 01	0.134687E 00	-0.219564E 01	-0.161150E 01	0.187338E 01

TEST NO. 0150 UNIT INTERVAL (T) = 0.133327E-05
 FAIR 9621/9620 RZ ISO DIST NO PROT TERM BAL POT 24 GA IP 750 KHPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.327082E-06	0.175021E-06	-0.478439E-06	0.116028E-08	0.327093E-06
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.245322E 02	0.131270E 02	-0.353844E 02	0.870251E-01	0.245330E 02

TEST NO. 0156 UNIT INTERVAL (T) = 0.200099E-05
 FAIR 9621/9620 RZ ISO DIST NO PROT TERM BAL POT 22 GA IP 500 KHZ

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.136135E-06	0.747571E-07	-0.196499E-06	0.190038E-08	0.136157E-06
PCT ERROR	-0.680336E 01	0.373601E 01	-0.192007E 01	0.949720E-01	0.680444E 01

TEST NO. 0157 UNIT INTERVAL (T) = 0.399890E-05
 FAIR 9621/9620 RZ ISO DIST NO PROT TERM BAL POT 22 GA IP 250 KHZ

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.471221E-07	0.118435E-07	-0.616542E-07	-0.200543E-07	0.471221E-07
PCT ERROR	-0.117836E 01	0.296196E 00	-0.154177E 01	-0.501495E 00	0.471221E-07

TEST NO. 0158 UNIT INTERVAL (T) = 0.995526E-05
 FAIR 9621/9620 RZ ISO DIST NO PROT TERM BAL POT 22 GA IP 100 KHZ

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.264201E-07	0.674858E-08	-0.390327E-07	-0.196332E-07	0.264201E-07
PCT ERROR	-0.265384E 00	0.678036E-01	-0.392001E 00	-0.197214E 00	0.265384E 00

TEST NO. 0159 UNIT INTERVAL (T) = 0.200220E-04
 FAIR 9621/9620 RZ ISO DIST NO PROT TERM BAL POT 22 GA IP 50 KHZ

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.429932E-07	0.368820E-08	-0.473101E-07	-0.356103E-07	0.429932E-07
PCT ERROR	-0.214726E 00	0.184540E-01	-0.235290E 00	-0.177855E 00	0.214726E 00

TEST NO. 0160 UNIT INTERVAL (T) = 0.333199E-06
 FAIR 9621/9620 RZ ISO DIST NO PROT TERM BAL POT 24 GA OP 3 MOPS

	MEAN	SD	MIN	MAX	AVER OF ABS
TIME ERROR	-0.549560E-07	0.315709E-07	-0.901399E-07	0.121000E-07	0.561496E-07
PCT ERROR	-0.164934E 02	0.947502E 01	-0.270708E 02	0.363148E 01	0.168516E 02

TEST NO. 0161 UNIT INTERVAL (T) = 0.49939E-06
 FAIR 9621/9620 KZ ISO DIST NO PROT TERM BAL POT 24 GA OP 2 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.396504E-07	0.220790E-07	-0.639198E-07	0.468012E-08	0.39986E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.793264E 01	-0.441720E 01	-0.127800E 02	0.133045E 01	0.800029E 01

TEST NO. 0162 UNIT INTERVAL (T) = 0.100009E-05
 FAIR 9621/9620 KZ ISO DIST NO PROT TERM BAL POT 24 GA OP 1 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.226522E-07	0.102292E-07	-0.369497E-07	-0.649720E-09	0.226522E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.226499E 01	0.102281F 01	-0.369460E 01	-0.649655E-01	0.226499E 01

TEST NO. 0163 UNIT INTERVAL (T) = 0.133294E-05
 FAIR 9621/9620 KZ ISO DIST NO PROT TERM BAL POT 24 GA OP 750 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.155989E-07	0.574656E-08	-0.256746E-07	-0.247462E-08	0.155989E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.117025E 01	0.431134F 00	-0.192615E 01	-0.185650E 00	0.117025E 01

TEST NO. 0164 UNIT INTERVAL (T) = 0.200066E-05
 FAIR 9621/9620 KZ ISO DIST NO PROT TERM BAL POT 24 GA OP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.976362E-08	0.312645E-08	-0.162344E-07	-0.493446E-08	0.976362E-08
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.488012E 00	0.156286E 00	-0.811452E 00	-0.246640E 00	0.488012E 00

TEST NO. 0165 UNIT INTERVAL (T) = 0.500029E-06
 FAIR 9621/9620 KZ ISO DIST NO PROT TERM BAL POT 22 GA OP 2 MBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.888968E-07	0.481905E-07	-0.135514E-06	0.978514E-08	0.895918E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.177783E 02	0.963748E 01	-0.271013E 02	0.195691E 01	0.179173E 02

TEST NO. 0166 UNIT INTERVAL (T) = 0.666319E-06
 FAIR 9621/9620 RZ ISO DIST NO PROT TERM BAL POT 22 GA OP 1.5 MBPS

TIME ERROR	MEAN	SD	MIN	AVER OF ABS
	-0.714206E-07	0.388839E-07	-0.108539E-06	0.514023E-08
PCT ERROR	MEAN	SD	MIN	AVER OF ABS
	-0.107186E 02	0.583561E 01	-0.162924E 02	0.771437E 00

TEST NO. 0167 UNIT INTERVAL (T) = 0.999999E-06
 FAIR 9621/9620 RZ ISO DIST NO PROT TERM BAL POT 22 GA OP 1 MBPS

TIME ERROR	MEAN	SD	MIN	AVER OF ABS
	-0.522556E-07	0.279262E-07	-0.748946E-07	0.499767E-09
PCT ERROR	MEAN	SD	MIN	AVER OF ABS
	-0.522555E 01	0.279266F 01	-0.748947E 01	0.499767E-01

TEST NO. 0168 UNIT INTERVAL (T) = 0.133342E-05
 FAIR 9621/9620 RZ ISO DIST NO PROT TERM BAL POT 22 GA OP 750 KBPS

TIME ERROR	MEAN	SD	MIN	AVER OF ABS
	-0.394213E-07	0.206797E-07	-0.577147E-07	0.394213E-07
PCT ERROR	MEAN	SD	MIN	AVER OF ABS
	-0.295637E 01	0.155087E 01	-0.432823E 01	0.761021E-01

TEST NO. 0169 UNIT INTERVAL (T) = 0.199880E-05
 FAIR 9621/9620 RZ ISO DIST NO PROT TERM BAL POT 22 GA OP 500 KBPS

TIME ERROR	MEAN	SD	MIN	AVER OF ABS
	-0.241352E-07	0.102567E-07	-0.366042E-07	0.241352E-07
PCT ERROR	MEAN	SD	MIN	AVER OF ABS
	-0.120748E 01	0.513145E 00	-0.181130E 01	0.120748E 01

TEST NO. 0170 UNIT INTERVAL (T) = 0.333129E-06
 FAIR 9621/9620 RZ ISO DIST NO PROT TERM BAL POT 19 GA OP 3 MBPS

TIME ERROR	MEAN	SD	MIN	AVER OF ABS
	-0.558397E-07	0.272607E-07	-0.912648E-07	0.558397E-07
PCT ERROR	MEAN	SD	MIN	AVER OF ABS
	-0.167621E 02	0.818322E 01	-0.273962E 02	0.167621E 02

TEST NO. 0171 UNIT INTERVAL (T) = 0.49649E-06
 FAIR 9621/9620 RZ ISO DIST NO PROT TERM BAL PUT 19 GA UP 2 Mbps

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.431271E-07	0.205707E-07	-0.56248E-07	0.375166E-09	0.431301E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.863150E 01	0.411694E 01	-0.132542E 02	0.750659E-01	0.863210E 01

TEST NO. 0172 UNIT INTERVAL (T) = 0.100002E-05
 FAIR 9621/9620 RZ ISO DIST NO PROT TERM BAL PUT 19 GA UP 1 Mbps

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.289759E-07	0.131650E-07	-0.414146E-07	-0.421471E-08	0.289759E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.289749E 01	0.131649E 01	-0.414134E 01	-0.421458E 00	0.289749E 01

TEST NO. 0173 UNIT INTERVAL (T) = 0.133338E-05
 FAIR 9621/9620 RZ ISO DIST NO PROT TERM BAL PUT 19 GA UP 850 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.253523E-07	0.109459E-07	-0.347947E-07	-0.479474E-08	0.253523E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.190133E 01	0.820924E 00	-0.260949E 01	-0.359590E 00	0.190133E 01

TEST NO. 0174 UNIT INTERVAL (T) = 0.200009E-05
 FAIR 9621/9620 RZ ISO DIST NO PROT TERM BAL PUT 19 GA UP 500 KBPS

TIME ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.202174E-07	0.739886E-08	-0.267493E-07	-0.624936E-08	0.202174E-07
PCT ERROR	MEAN	SD	MIN	MAX	AVER OF ABS
	-0.101082E 01	0.369930E 00	-0.133740E 01	-0.312452E 00	0.101082E 01

TEST NO. 0075 UNIT INTERVAL (T) = 0.999259E-06
 PAIR 2621/2620 BIPHASE 1SD DIST NO PROT TERM BAL POT 1000 FT 24 GA IP 1 Mbps
 UNIT INTERVAL (T) = 0.999259E-06
 DATA TIME MEASUREMENT TIME ERROR TIME ERROR
 INTERVAL (IN SECONDS) (IN SECONDS) (IN PERCENT OF T)

1	0.905600E-06	-0.936592E-07	-0.937286E 01
2	0.616399E-06	0.116770E-06	0.116856E 02
3	0.106810E-05	0.688408E-07	0.688918E 01
4	0.240699E-06	-0.258929E-06	-0.259121E 02
5	0.240500E-06	-0.259129E-06	-0.259321E 02
6	0.970600E-06	-0.296593E-07	-0.286805E 01
7	0.970600E-06	-0.286593E-07	-0.286805E 01
8	0.112749E-05	0.128240E-06	0.128335E 02
9	0.449499E-06	-0.501296E-07	-0.501668E 01
10	0.433299E-06	-0.663296E-07	-0.663788E 01
11	0.384600E-06	-0.115029E-06	-0.115114E 02
12	0.208699E-06	-0.290929E-06	-0.291145E 02
13	0.208800E-06	-0.290829E-06	-0.291045E 02
14	0.612199E-06	0.112570E-06	0.112653E 02
15	0.105150E-05	0.522407E-07	0.522794E 01
16	0.178899E-06	-0.320729E-06	-0.320967E 02
17	0.178800E-06	-0.320829E-06	-0.321067E 02
18	0.524000E-06	0.243703E-07	0.243884E 01
19	0.635899E-06	0.136270E-06	0.136371E 02
20	0.112920E-05	0.129940E-06	0.130037E 02
21	0.452199E-06	-0.474296E-07	-0.474648E 01
22	0.435000E-06	-0.646296E-07	-0.646775E 01
23	0.382300E-06	-0.117329E-06	-0.117416E 02
24	0.189900E-06	-0.309729E-06	-0.309959E 02
25	0.190099E-06	-0.309529E-06	-0.309759E 02
26	0.572799E-06	0.731703E-07	0.732245E 01
27	0.911899E-06	-0.873592E-07	-0.874240E 01
28	0.911799E-06	-0.874592E-07	-0.875241E 01
29	0.522400E-06	0.227703E-07	0.227872E 01
30	0.624899E-06	0.125270E-06	0.125363E 02
31	0.110580E-05	0.106540E-06	0.106619E 02
32	0.400899E-06	-0.987296E-07	-0.988028E 01
33	0.264400E-06	-0.235229E-06	-0.235404E 02
34	0.264499E-06	-0.235129E-06	-0.235303E 02
35	0.113019E-05	0.130940E-06	0.131037E 02
36	0.465299E-06	-0.343296E-07	-0.343550E 01
37	0.452000E-06	-0.476295E-07	-0.476648E 01
38	0.429599E-06	-0.700296E-07	-0.700815E 01
39	0.366800E-06	-0.132829E-06	-0.132928E 02
40	0.166499E-06	-0.333129E-06	-0.333376E 02
41	0.166499E-06	-0.333129E-06	-0.333376E 02
42	0.489700E-06	-0.992963E-08	-0.993699E 00
43	0.526499E-06	0.268702E-07	0.268901E 01
44	0.626100E-06	0.126470E-06	0.126564E 02
45	0.110040E-05	0.101140E-06	0.101215E 02
46	0.372600E-06	-0.127029E-06	-0.127123E 02
47	0.170400E-06	-0.329229E-06	-0.329473E 02
48	0.170499E-06	-0.329129E-06	-0.329373E 02
49	0.468800E-06	-0.308296E-07	-0.308524E 01

50	0.467699E-06	-0.319296E-07	-0.319543E 01
51	0.470700E-06	-0.289296E-07	-0.289510E 01
52	0.486799E-06	-0.128296E-07	-0.128391E 01
53	0.522299E-06	0.226707E-07	0.226871E 01
54	0.627600E-06	0.127970E-06	0.128065E 02
55	0.112680E-05	0.127540E-06	0.127635E 02
56	0.463899E-06	-0.357296E-07	-0.357561E 01
57	0.463800E-06	-0.358296E-07	-0.358561E 01
58	0.463099E-06	-0.365296E-07	-0.365567E 01
59	0.464399E-06	-0.352296E-07	-0.352557E 01
60	0.462400E-06	-0.372296E-07	-0.372572E 01
61	0.448399E-06	-0.512296E-07	-0.512676E 01
62	0.428600E-06	-0.710296E-07	-0.710822E 01
63	0.369100E-06	-0.130529E-06	-0.130626E 02
64	0.184800E-06	-0.314829E-06	-0.315062E 02
65	0.184599E-06	-0.315029E-06	-0.315263E 02
66	0.526600E-06	0.269703E-07	0.269903E 01
67	0.628299E-06	0.128670E-06	0.128765E 02
68	0.109849E-05	0.992406E-07	0.993142E 01
69	0.373100E-06	-0.126529E-06	-0.126623E 02
70	0.183499E-06	-0.316129E-06	-0.316363E 02
71	0.133400E-06	-0.316229E-06	-0.316464E 02
72	0.497400E-06	-0.222962E-08	-0.223127E 00
73	0.579899E-06	0.802703E-07	0.803298E 01
74	0.929599E-06	-0.696592E-07	-0.697108E 01
75	0.929799E-06	-0.694592E-07	-0.695107E 01
76	0.627299E-06	0.127670E-06	0.127764E 02
77	0.111059E-05	0.111340E-06	0.111423E 02
78	0.402499E-06	-0.971296E-07	-0.972016E 01
79	0.468699E-06	-0.309296E-07	-0.309525E 01
80	0.251199E-06	-0.248429E-06	-0.248613E 02
81	0.105939E-05	0.601405E-07	0.601851E 01
82	0.191099E-06	-0.308529E-06	-0.308758E 02
83	0.191099E-06	-0.308529E-06	-0.308758E 02
84	0.589699E-06	0.900703E-07	0.901371E 01
85	0.953100E-06	-0.461591E-07	-0.461933E 01
86	0.952899E-06	-0.463592E-07	-0.463935E 01
87	0.968899E-06	-0.303593E-07	-0.303818E 01
88	0.969100E-06	-0.301593E-07	-0.301816E 01
89	0.110769E-05	0.108440E-06	0.108521E 02
90	0.401100E-06	-0.985296E-07	-0.986026E 01
91	0.266699E-06	-0.232929E-06	-0.233102E 02
92	0.266499E-06	-0.233129E-06	-0.233302E 02
93	0.112130E-05	0.122040E-06	0.122131E 02
94	0.442699E-06	-0.569296E-07	-0.569718E 01
95	0.391000E-06	-0.108629E-06	-0.108710E 02
96	0.248099E-06	-0.251529E-06	-0.251716E 02
97	0.248200E-06	-0.251429E-06	-0.251616E 02
98	0.942799E-06	-0.564592E-07	-0.565011E 01
99	0.942499E-06	-0.567592E-07	-0.568013E 01
100	0.909700E-06	-0.895592E-07	-0.896256E 01
101	0.909700E-06	-0.895592E-07	-0.896256E 01
102	0.524299E-06	0.246702E-07	0.246885E 01
103	0.635699E-06	0.136070E-06	0.136171E 02
104	0.112160E-05	0.122340E-06	0.122431E 02
105	0.443600E-06	-0.560295E-07	-0.560711E 01

106	0.387800E-06	-0.111829E-06	-0.111912E 02
107	0.236400E-06	-0.263229E-06	-0.263424E 02
108	0.236499E-06	-0.263129E-06	-0.263324E 02
109	0.920499E-06	-0.787592E-07	-0.788176E 01
110	0.920600E-06	-0.786591E-07	-0.787174E 01
111	0.590300E-06	0.906703E-07	0.907376E 01
112	0.956100E-06	-0.431591E-07	-0.431911E 01
113	0.956000E-06	-0.432592E-07	-0.432912E 01
114	0.946100E-06	-0.531591E-07	-0.531985E 01
115	0.946100E-06	-0.529592E-07	-0.529984E 01
116	0.902899E-06	-0.963592E-07	-0.964307E 01
117	0.902699E-06	-0.965592E-07	-0.966308E 01
118	0.472400E-06	-0.272295E-07	-0.272497E 01
119	0.482300E-06	-0.173296E-07	-0.173424E 01
120	0.506300E-06	0.667034E-08	0.667529E 00
121	0.503199E-06	0.935703E-07	0.936396E 01
122	0.970100E-06	-0.291593E-07	-0.291809E 01
123	0.970200E-06	-0.290592E-07	-0.290808E 01
124	0.112670E-05	0.127440E-06	0.127535E 02
125	0.465399E-06	-0.342296E-07	-0.342550E 01
126	0.465499E-06	-0.341296E-07	-0.341549E 01
127	0.461199E-06	-0.384296E-07	-0.384581E 01
128	0.450900E-06	-0.487295E-07	-0.487657E 01
129	0.441899E-06	-0.577296E-07	-0.577724E 01
130	0.390100E-06	-0.109529E-06	-0.109610E 02
131	0.246800E-06	-0.252829E-06	-0.253017E 02
132	0.247200E-06	-0.252429E-06	-0.252616E 02
133	0.952599E-06	-0.466592E-07	-0.466938E 01
134	0.952599E-06	-0.466592E-07	-0.466938E 01
135	0.951200E-06	-0.480591E-07	-0.480948E 01
136	0.951400E-06	-0.478592E-07	-0.478946E 01
137	0.952000E-06	-0.472591E-07	-0.472942E 01
138	0.951700E-06	-0.475591E-07	-0.475944E 01
139	0.972000E-06	-0.272591E-07	-0.272793E 01
140	0.971800E-06	-0.274592E-07	-0.274796E 01
141	0.112169E-05	0.122440E-06	0.122531E 02
142	0.443600E-06	-0.560295E-07	-0.560711E 01
143	0.388499E-06	-0.111129E-06	-0.111212E 02
144	0.234200E-06	-0.265429E-06	-0.265626E 02
145	0.234000E-06	-0.265629E-06	-0.265826E 02
146	0.902399E-06	-0.968592E-07	-0.969310E 01
147	0.902300E-06	-0.969591E-07	-0.970310E 01
148	0.490099E-06	-0.952968E-08	-0.953675E 00
149	0.524799E-06	0.251702E-07	0.251889E 01
150	0.624800E-06	0.125170E-06	0.125263E 02
151	0.110859E-05	0.109340E-06	0.109421E 02
152	0.390000E-06	-0.109629E-06	-0.109710E 02
153	0.235900E-06	-0.264729E-06	-0.264925E 02
154	0.235199E-06	-0.264429E-06	-0.264625E 02
155	0.919400E-06	-0.798592E-07	-0.799184E 01
156	0.919299E-06	-0.799592E-07	-0.800185E 01
157	0.573000E-06	0.733704E-07	0.734248E 01
158	0.914300E-06	-0.849592E-07	-0.850222E 01
159	0.914199E-06	-0.850592E-07	-0.851223E 01
160	0.517300E-06	0.176703E-07	0.176834E 01
161	0.611100E-06	0.111470E-06	0.111553E 02

162	0.105880E-05	0.595407E-07	0.595849E 01
163	0.187099E-06	-0.312529E-06	-0.312761E 02
164	0.187099E-06	-0.312529E-06	-0.312761E 02
165	0.598600E-06	0.989704E-07	0.990438E 01
166	0.963899E-06	-0.353593E-07	-0.353855E 01
167	0.963700E-06	-0.355592E-07	-0.355855E 01
168	0.106869E-05	0.694406E-07	0.694920E 01
169	0.246599E-06	-0.253029E-06	-0.253217E 02
170	0.246800E-06	-0.252829E-06	-0.253017E 02
171	0.960299E-06	-0.389593E-07	-0.389882E 01
172	0.960100E-06	-0.391592E-07	-0.391882E 01
173	0.105809E-05	0.588406E-07	0.588843E 01
174	0.204799E-06	-0.294829E-06	-0.295048E 02
175	0.205000E-06	-0.294629E-06	-0.294848E 02
176	0.638600E-06	0.138970E-06	0.139073E 02
177	0.112079E-05	0.121540E-06	0.121630E 02
178	0.442399E-06	-0.572296E-07	-0.572720E 01
179	0.389499E-06	-0.110129E-06	-0.110211E 02
180	0.250100E-06	-0.249529E-06	-0.249714E 02
181	0.250400E-06	-0.249229E-06	-0.249414E 02
182	0.962299E-06	-0.369593E-07	-0.369867E 01
183	0.962700E-06	-0.365591E-07	-0.365862E 01
184	0.105160E-05	0.523407E-07	0.523795E 01
185	0.186199E-06	-0.313429E-06	-0.313661E 02
186	0.186499E-06	-0.313129E-06	-0.313361E 02
187	0.516100E-06	0.164703E-07	0.164825E 01
188	0.608700E-06	0.109070E-06	0.109151E 02
189	0.105829E-05	0.590405E-07	0.590843E 01
190	0.199299E-06	-0.300329E-06	-0.300552E 02
191	0.199400E-06	-0.300229E-06	-0.300452E 02
192	0.638200E-06	0.138570E-06	0.138673E 02
193	0.113049E-05	0.131240E-06	0.131337E 02
194	0.464899E-06	-0.347296E-07	-0.347553E 01
195	0.450699E-06	-0.489296E-07	-0.489659E 01
196	0.432199E-06	-0.674296E-07	-0.674796E 01
197	0.193700E-06	-0.305929E-06	-0.306156E 02
198	0.193599E-06	-0.306029E-06	-0.306256E 02
199	0.592000E-06	0.923704E-07	0.924389E 01
200	0.954000E-06	-0.452591E-07	-0.452927E 01
201	0.953800E-06	-0.454592E-07	-0.454929E 01
202	0.953600E-06	-0.456591E-07	-0.456929E 01
203	0.953700E-06	-0.455593E-07	-0.455930E 01
204	0.944899E-06	-0.543592E-07	-0.543995E 01
205	0.944899E-06	-0.543592E-07	-0.543995E 01
206	0.927600E-06	-0.716592E-07	-0.717123E 01
207	0.927799E-06	-0.714592E-07	-0.715122E 01
208	0.610100E-06	0.110470E-06	0.110552E 02
209	0.106230E-05	0.630407E-07	0.630874E 01
210	0.201700E-06	-0.297929E-06	-0.298150E 02
211	0.201599E-06	-0.298029E-06	-0.298250E 02
212	0.615199E-06	0.115570E-06	0.115655E 02
213	0.106090E-05	0.616407E-07	0.616864E 01
214	0.189099E-06	-0.310529E-06	-0.310759E 02
215	0.189399E-06	-0.310229E-06	-0.310459E 02
216	0.589600E-06	0.899704E-07	0.900371E 01
217	0.943499E-06	-0.557593E-07	-0.558006E 01


218	0.943100E-06	-0.561591E-07	-0.562007E 01
219	0.926000E-06	-0.732591E-07	-0.733134E 01
220	0.926100E-06	-0.731591E-07	-0.732134E 01
221	0.635399E-06	0.135770E-06	0.135870E 02
222	0.112880E-05	0.129540E-06	0.129636E 02
223	0.454200E-06	-0.454296E-07	-0.454632E 01
224	0.442899E-06	-0.567296E-07	-0.567716E 01
225	0.386099E-06	-0.113529E-06	-0.113613E 02
226	0.234499E-06	-0.265129E-06	-0.265326E 02
227	0.234400E-06	-0.265229E-06	-0.265426E 02
228	0.929399E-06	-0.698593E-07	-0.699111E 01
229	0.929299E-06	-0.699592E-07	-0.700111E 01
230	0.628900E-06	0.129270E-06	0.129366E 02
231	0.109989E-05	0.100640E-06	0.100715E 02
232	0.371300E-06	-0.128329E-06	-0.128424E 02
233	0.173300E-06	-0.326329E-06	-0.326571E 02
234	0.173399E-06	-0.326229E-06	-0.326471E 02
235	0.483100E-06	-0.165296E-07	-0.165418E 01
236	0.501200E-06	0.157035E-08	0.157152E 00
237	0.571699E-06	0.720703E-07	0.721237E 01
238	0.912800E-06	-0.864591E-07	-0.865233E 01
239	0.912600E-06	-0.866591E-07	-0.867234E 01
240	0.516899E-06	0.172702E-07	0.172830E 01
241	0.619600E-06	0.119970E-06	0.120059E 02
242	0.107759E-05	0.783404E-07	0.783985E 01
243	0.250000E-06	-0.249629E-06	-0.249814E 02
244	0.250200E-06	-0.249429E-06	-0.249614E 02
245	0.106109E-05	0.618406E-07	0.618864E 01
246	0.190400E-06	-0.309229E-06	-0.309458E 02
247	0.190499E-06	-0.309129E-06	-0.309358E 02
248	0.575599E-06	0.759703E-07	0.760266E 01
249	0.912699E-06	-0.865592E-07	-0.866234E 01
250	0.912699E-06	-0.865592E-07	-0.866234E 01
251	0.509000E-06	0.937041E-08	0.937735E 00
252	0.588600E-06	0.889704E-07	0.890363E 01
253	0.945100E-06	-0.541591E-07	-0.541993E 01
254	0.944800E-06	-0.544591E-07	-0.544995E 01
255	0.925899E-06	-0.733592E-07	-0.734136E 01
256	0.925699E-06	-0.735592E-07	-0.736137E 01
257	0.616100E-06	0.116470E-06	0.116556E 02
258	0.107759E-05	0.783404E-07	0.783985E 01
259	0.265600E-06	-0.234029E-06	-0.234203E 02
260	0.265600E-06	-0.234029E-06	-0.234203E 02
261	0.111880E-05	0.119540E-06	0.119629E 02
262	0.443100E-06	-0.565295E-07	-0.565715E 01
263	0.403000E-06	-0.966296E-07	-0.967012E 01
264	0.265799E-06	-0.233829E-06	-0.234002E 02
265	0.265699E-06	-0.233929E-06	-0.234103E 02
266	0.110890E-05	0.109640E-06	0.109722E 02
267	0.389100E-06	-0.110529E-06	-0.110611E 02
268	0.243000E-06	-0.256629E-06	-0.256819E 02
269	0.243000E-06	-0.256629E-06	-0.256819E 02
270	0.953399E-06	-0.458592E-07	-0.458932E 01
271	0.953000E-06	-0.462591E-07	-0.462934E 01
272	0.971000E-06	-0.282591E-07	-0.282800E 01
273	0.971100E-06	-0.281593E-07	-0.281802E 01


274	0.110090E-05	0.101640E-06	0.101716E 02
275	0.383899E-06	-0.115729E-06	-0.115815E 02
276	0.203699E-06	-0.295929E-06	-0.296148E 02
277	0.203799E-06	-0.295829E-06	-0.296048E 02
278	0.612199E-06	0.112570E-06	0.112653E 02
279	0.106039E-05	0.611405E-07	0.611858E 01
280	0.201499E-06	-0.298129E-06	-0.298350E 02
281	0.201599E-06	-0.298029E-06	-0.298250E 02
282	0.631899E-06	0.132270E-06	0.132368E 02
283	0.110819E-05	0.108940E-06	0.109021E 02
284	0.262900E-06	-0.236729E-06	-0.236905E 02
285	0.262800E-06	-0.236829E-06	-0.237005E 02
286	0.110979E-05	0.110540E-06	0.110622E 02
287	0.403400E-06	-0.962296E-07	-0.963009E 01
288	0.264199E-06	-0.235429E-06	-0.235604E 02
289	0.264400E-06	-0.235229E-06	-0.235404E 02
290	0.110049E-05	0.101240E-06	0.101315E 02
291	0.382499E-06	-0.117129E-06	-0.117216E 02
292	0.206199E-06	-0.293429E-06	-0.293647E 02
293	0.206199E-06	-0.293429E-06	-0.293647E 02
294	0.633600E-06	0.133970E-06	0.134069E 02
295	0.110840E-05	0.109140E-06	0.109221E 02
296	0.392000E-06	-0.107629E-06	-0.107709E 02
297	0.244400E-06	-0.255229E-06	-0.255418E 02
298	0.244600E-06	-0.255029E-06	-0.255218E 02
299	0.943600E-06	-0.556591E-07	-0.557004E 01
300	0.943600E-06	-0.556591E-07	-0.557004E 01
301	0.928600E-06	-0.706592E-07	-0.707116E 01
302	0.928700E-06	-0.705591E-07	-0.706114E 01
303	0.629499E-06	0.129870E-06	0.129966E 02
304	0.111040E-05	0.111140E-06	0.111223E 02
305	0.232600E-06	-0.267029E-06	-0.267227E 02
306	0.232699E-06	-0.266929E-06	-0.267127E 02
307	0.901499E-06	-0.977593E-07	-0.978318E 01
308	0.901499E-06	-0.977593E-07	-0.978318E 01
309	0.471600E-06	-0.280296E-07	-0.280503E 01
310	0.489800E-06	-0.982959E-08	-0.983687E 00
311	0.524700E-06	0.250703E-07	0.250889E 01
312	0.629599E-06	0.129970E-06	0.130066E 02
313	0.111899E-05	0.119740E-06	0.119829E 02
314	0.444100E-06	-0.555296E-07	-0.555707E 01
315	0.398800E-06	-0.100829E-06	-0.100904E 02
316	0.253300E-06	-0.246329E-06	-0.246512E 02
317	0.253300E-06	-0.246329E-06	-0.246512E 02
318	0.108029E-05	0.810405E-07	0.811006E 01
319	0.266899E-06	-0.232729E-06	-0.232902E 02
320	0.267199E-06	-0.232429E-06	-0.232601E 02
321	0.110090E-05	0.101640E-06	0.101716E 02
322	0.368899E-06	-0.130729E-06	-0.130826E 02
323	0.171099E-06	-0.328529E-06	-0.328773E 02
324	0.170800E-06	-0.328829E-06	-0.329073E 02
325	0.490099E-06	-0.952968E-08	-0.953675E 00
326	0.518700E-06	0.190704E-07	0.190845E 01
327	0.608599E-06	0.108970E-06	0.109051E 02
328	0.105389E-05	0.546406E-07	0.546811E 01
329	0.181000E-06	-0.318629E-06	-0.318865E 02


330	0.181300E-06	-0.318329E-06	-0.318565E 02
331	0.500599E-06	0.970317E-09	0.971036E-01
332	0.581399E-06	0.817702E-07	0.818309E 01
333	0.922699E-06	-0.765592E-07	-0.766159E 01
334	0.922799E-06	-0.764593E-07	-0.765159E 01
335	0.588399E-06	0.887703E-07	0.888361E 01
336	0.945899E-06	-0.533592E-07	-0.533988E 01
337	0.945899E-06	-0.533592E-07	-0.533988E 01
338	0.919200E-06	-0.800591E-07	-0.801185E 01
339	0.919400E-06	-0.798592E-07	-0.799184E 01
340	0.596099E-06	0.964703E-07	0.965418E 01
341	0.961799E-06	-0.374593E-07	-0.374871E 01
342	0.961500E-06	-0.377592E-07	-0.377872E 01
343	0.106020E-05	0.609407E-07	0.609858E 01
344	0.205199E-06	-0.294429E-06	-0.294647E 02
345	0.205499E-06	-0.294129E-06	-0.294347E 02
346	0.626499E-06	0.126870E-06	0.126964E 02
347	0.107000E-05	0.707407E-07	0.707931E 01
348	0.228499E-06	-0.271129E-06	-0.271330E 02
349	0.228200E-06	-0.271429E-06	-0.271630E 02
350	0.912800E-06	-0.864591E-07	-0.865233E 01
351	0.912800E-06	-0.864591E-07	-0.865233E 01
352	0.501099E-06	0.147031E-08	0.147140E 00
353	0.574499E-06	0.748703E-07	0.749258E 01
354	0.911000E-06	-0.882591E-07	-0.883246E 01
355	0.911299E-06	-0.879592E-07	-0.880245E 01
356	0.508299E-06	0.867032E-08	0.867675E 00
357	0.596900E-06	0.972703E-07	0.973424E 01
358	0.965399E-06	-0.338593E-07	-0.338844E 01
359	0.965200E-06	-0.340592E-07	-0.340844E 01
360	0.231900E-06	-0.267729E-06	-0.267928E 02
361	0.232099E-06	-0.267529E-06	-0.267727E 02
362	0.918000E-06	-0.812591E-07	-0.813194E 01
363	0.918100E-06	-0.811592E-07	-0.812194E 01
364	0.595799E-06	0.961703E-07	0.962416E 01
365	0.972300E-06	-0.269592E-07	-0.269792E 01
366	0.972000E-06	-0.272591E-07	-0.272793E 01
367	0.110849E-05	0.109240E-06	0.109321E 02
368	0.386699E-06	-0.112929E-06	-0.113013E 02
369	0.233400E-06	-0.266229E-06	-0.266426E 02
370	0.233300E-06	-0.266329E-06	-0.266527E 02
371	0.928700E-06	-0.705591E-07	-0.706114E 01
372	0.928700E-06	-0.705591E-07	-0.706114E 01
373	0.609799E-06	0.110170E-06	0.110251E 02
374	0.105319E-05	0.539405E-07	0.539805E 01
375	0.179000E-06	-0.320629E-06	-0.320867E 02
376	0.179199E-06	-0.320429E-06	-0.320667E 02
377	0.509700E-06	0.100703E-07	0.100778E 01
378	0.598600E-06	0.989704E-07	0.990438E 01
379	0.964899E-06	-0.343593E-07	-0.343848E 01
380	0.965000E-06	-0.342593E-07	-0.342847E 01
381	0.105189E-05	0.526406E-07	0.526796E 01
382	0.168499E-06	-0.331129E-06	-0.331375E 02
383	0.168699E-06	-0.330929E-06	-0.331175E 02
384	0.470600E-06	-0.290295E-07	-0.290511E 01
385	0.477000E-06	-0.226295E-07	-0.226463E 01


386	0.484679E-06	-0.149297E-07	-0.149407E 01
387	0.510800E-06	0.111704E-07	0.111786E 01
388	0.589100E-06	0.894704E-07	0.895367E 01
389	0.947300E-06	-0.519592E-07	-0.519977E 01
390	0.947199E-06	-0.520592E-07	-0.520978E 01
391	0.918900E-06	-0.803592E-07	-0.804187E 01
392	0.918900E-06	-0.803592E-07	-0.804187E 01
393	0.578600E-06	0.789704E-07	0.790289E 01
394	0.918700E-06	-0.805591E-07	-0.806189E 01
395	0.918700E-06	-0.805591E-07	-0.806189E 01
396	0.593399E-06	0.937702E-07	0.938397E 01
397	0.971399E-06	-0.278594E-07	-0.278800E 01
398	0.971399E-06	-0.278594E-07	-0.278800E 01
399	0.112530E-05	0.126040E-06	0.126134E 02
400	0.450300E-06	-0.493295E-07	-0.493661E 01
401	0.443600E-06	-0.560295E-07	-0.560711E 01
402	0.402399E-06	-0.972296E-07	-0.973017E 01
403	0.268900E-06	-0.230729E-06	-0.230900E 02
404	0.268900E-06	-0.230729E-06	-0.230900E 02
405	0.111949E-05	0.120240E-06	0.120329E 02
406	0.370800E-06	-0.128829E-06	-0.128925E 02
407	0.187099E-06	-0.312529E-06	-0.312761E 02
408	0.187400E-06	-0.312229E-06	-0.312461E 02
409	0.518399E-06	0.187702E-07	0.187841E 01
410	0.609799E-06	0.110170E-06	0.110251E 02
411	0.105200E-05	0.527406E-07	0.527797E 01
412	0.181199E-06	-0.318429E-06	-0.318665E 02
413	0.181199E-06	-0.318429E-06	-0.318665E 02
414	0.515800E-06	0.161703E-07	0.161823E 01
415	0.617299E-06	0.117670E-06	0.117757E 02
416	0.107749E-05	0.782406E-07	0.782986E 01
417	0.263800E-06	-0.235829E-06	-0.236004E 02
418	0.263800E-06	-0.235829E-06	-0.236004E 02
419	0.111200E-05	0.112740E-06	0.112824E 02
420	0.401600E-06	-0.980296E-07	-0.981023E 01
421	0.252700E-06	-0.246929E-06	-0.247112E 02
422	0.252599E-06	-0.247029E-06	-0.247212E 02
423	0.104950E-05	0.502407E-07	0.502779E 01
424	0.166499E-06	-0.333129E-06	-0.333376E 02
425	0.166799E-06	-0.332829E-06	-0.333076E 02
426	0.487499E-06	-0.121297E-07	-0.121386E 01
427	0.525000E-06	0.253703E-07	0.253891E 01
428	0.631499E-06	0.131870E-06	0.131968E 02
429	0.111869E-05	0.119440E-06	0.119529E 02
430	0.433100E-06	-0.665296E-07	-0.665789E 01
431	0.380899E-06	-0.118729E-06	-0.118917E 02
432	0.187300E-06	-0.312329E-06	-0.312561E 02
433	0.187300E-06	-0.312329E-06	-0.312561E 02
434	0.582000E-06	0.823704E-07	0.824315E 01
435	0.930700E-06	-0.685592E-07	-0.686100E 01
436	0.930400E-06	-0.688592E-07	-0.689102E 01
437	0.627299E-06	0.127670E-06	0.127764E 02
438	0.110020E-05	0.100940E-06	0.101015E 02
439	0.382099E-06	-0.117529E-06	-0.117616E 02
440	0.191400E-06	-0.308229E-06	-0.308458E 02
441	0.191800E-06	-0.307829E-06	-0.308057E 02


442	0.600199E-06	0.100570E-06	0.100644E 02
443	0.963799E-06	-0.354593E-07	-0.354856E 01
444	0.963700E-06	-0.355592E-07	-0.355855E 01
445	0.105339E-05	0.541406E-07	0.541807E 01
446	0.185900E-06	-0.313729E-06	-0.313962E 02
447	0.185900E-06	-0.313729E-06	-0.313962E 02
448	0.500099E-06	0.470322E-09	0.470671E-01
449	0.573299E-06	0.736703E-07	0.737249E 01
450	0.903600E-06	-0.956591E-07	-0.957301E 01
451	0.903399E-06	-0.958592E-07	-0.959303E 01
452	0.488300E-06	-0.113295E-07	-0.113379E 01
453	0.515000E-06	0.153703E-07	0.153817E 01
454	0.612399E-06	0.112770E-06	0.112853E 02
455	0.107519E-05	0.759405E-07	0.759968E 01
456	0.263199E-06	-0.236429E-06	-0.236604E 02
457	0.263599E-06	-0.236029E-06	-0.236204E 02
458	0.112819E-05	0.128940E-06	0.129036E 02
459	0.465800E-06	-0.338295E-07	-0.338546E 01
460	0.463099E-06	-0.365296E-07	-0.365567E 01
461	0.447099E-06	-0.525296E-07	-0.525685E 01
462	0.430599E-06	-0.690296E-07	-0.690808E 01
463	0.383100E-06	-0.116529E-06	-0.116615E 02
464	0.210800E-06	-0.288829E-06	-0.289043E 02
465	0.210800E-06	-0.288829E-06	-0.289043E 02
466	0.633499E-06	0.133870E-06	0.133969E 02
467	0.109799E-05	0.987406E-07	0.988138E 01
468	0.371499E-06	-0.128129E-06	-0.128224E 02
469	0.185900E-06	-0.313729E-06	-0.313962E 02
470	0.185700E-06	-0.313929E-06	-0.314162E 02
471	0.518399E-06	0.187702E-07	0.187841E 01
472	0.618900E-06	0.119270E-06	0.119358E 02
473	0.107059E-05	0.713405E-07	0.713934E 01
474	0.242599E-06	-0.257029E-06	-0.257220E 02
475	0.242900E-06	-0.256729E-06	-0.256919E 02
476	0.945800E-06	-0.534591E-07	-0.534988E 01
477	0.945899E-06	-0.533592E-07	-0.533988E 01
478	0.921399E-06	-0.778592E-07	-0.779169E 01
479	0.921499E-06	-0.777593E-07	-0.778169E 01
480	0.590100E-06	0.904704E-07	0.905374E 01
481	0.945800E-06	-0.534591E-07	-0.534988E 01
482	0.945600E-06	-0.536591E-07	-0.536989E 01
483	0.905399E-06	-0.938592E-07	-0.939288E 01
484	0.905499E-06	-0.937592E-07	-0.938287E 01
485	0.485300E-06	-0.143296E-07	-0.143402E 01
486	0.503500E-06	0.387035E-08	0.387322E 00
487	0.905700E-06	-0.935591E-07	-0.936285E 01
488	0.905600E-06	-0.936592E-07	-0.937286E 01
489	0.483500E-06	-0.161296E-07	-0.161416E 01
490	0.502200E-06	0.257034E-08	0.257225E 00
491	0.579000E-06	0.793703E-07	0.794292E 01
492	0.920499E-06	-0.787592E-07	-0.788176E 01
493	0.920200E-06	-0.790592E-07	-0.791178E 01
494	0.594000E-06	0.943704E-07	0.944404E 01
495	0.961100E-06	-0.381592E-07	-0.381875E 01
496	0.961200E-06	-0.380591E-07	-0.380873E 01
497	0.107569E-05	0.764495E-07	0.764972E 01
498	0.265600E-06	-0.234029E-06	-0.234203E 02
499	0.265699E-06	-0.233929E-06	-0.234103E 02
500	0.112710E-05	0.127840E-06	0.127935E 02

























































TEST NO. 50019














I-71

























































































































I-110






































































































































































I-165









































































































































UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER RADC-TR-74-258, Volume I (of two)	2. GOVT ACCESSION NO.	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) AIR FORCE COMMUNICATIONS SERVICE DIGITAL TRANSMISSION STUDY Volume I - Test Results Appendix - Computer Analysis of Isochronous Distortion Data		5. TYPE OF REPORT & PERIOD COVERED Final Report
7. AUTHOR(s) R.M. Houston		6. PERFORMING ORG. REPORT NUMBER None
8. PERFORMING ORGANIZATION NAME AND ADDRESS Computer Sciences Corporation 6565 Arlington Boulevard Falls Church, Virginia 22046		6. CONTRACT OR GRANT NUMBER(s) F30602-72-C-0504
11. CONTROLLING OFFICE NAME AND ADDRESS Rome Air Development Center (DCLD) Griffiss Air Force Base, New York 13441		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS .R1140101
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office) Same		12. REPORT DATE October 1974
		13. NUMBER OF PAGES 212
		15. SECURITY CLASS. (of this report) Unclassified
		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE N/A
16. DISTRIBUTION STATEMENT (of this Report) Distribution limited to US Gov't agencies only; test end evaluation; October 74. Other requests for this document must be referred to RADC(DCLD), GAFB, NY13441.		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report) Same		
18. SUPPLEMENTARY NOTES Data Transmission Telephone Cables Integrated Circuits Digital Measurements		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Data Transmission Telephone Cables Integrated Circuits Digital Measurements		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) Extensive measurements and predictions have been made at data rates up to 10 megabits per second to characterize the digital transmission of binary (+1,-1) signals over balanced pair cables up to 100,000 feet in length. This report presents the results of experimentation concerned with the transmission of digital signals using existing Air Force multi-pair cables and common station equipment. Integrated circuit line drivers and receivers were used for the Balanced Transmission Devices. It has been demonstrated that the		

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

20. ABSTRACT (continued)

transmission capability of existing cable plant can be predicted.

Volume I of the report presents the reduced data from the entire test program including laboratory tests, field tests at Patrick Air Force Base, and computer simulation.

Volume II is a handbook for the use of Air Force Communication Services to engineer digital cable transmission facilities. The handbook contains tutorial material as well as step-by-step procedures for the design of digital cable systems.

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)